

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Corix Utilities Texas, Inc (CN604520213) operates Ridge Harbor WWTF RN102078748. an activated sludge process plant using the conventional mode. The facility is located at 1195 Ridge Harbor Drive, in Spicewood, Burnet County, Texas 78669.

The permittee requests renewed authorization to dispose of treated domestic wastewater effluent at a daily average flow not to exceed 0.018 million gallons per day (MGD) via non-public access low pressure dosing drainfields with a minimum area of 180,000 square feet in the Interim I phase, a daily average flow not to exceed 0.025 MGD via non-public access low pressure dosing drainfields with a minimum area of 250,000 square feet in the Interim II phase, and a daily average flow not to exceed 0.035 MGD via non-public access low pressure dosing drainfields with a minimum area of 350,000 square feet in the Final phase. Application rates to the subsurface irrigated land shall not exceed 0.1 gallons per square foot per day. The permittee shall maintain Bermuda grass and ryegrass on the disposal site. This permit will not authorize a discharge of pollutants into water in the state.

Land applied discharges from the facility are expected to contain no pollutants beyond five-day biochemical oxygen demand (BOD₅) not to exceed single grab sample of 65 mg/L, and total suspended solids (TSS) not to exceed 65 mg/L. The pH of the effluent shall not be less than 6 or greater than 9. Land applied effluent is treated by aeration basin, final clarifier, and aerobic digester.