

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

North Alamo Water Supply Corporation (CN600633713) operates the San Carlos Wastewater Treatment Facility (RN2341013), a pond system. The facility is located approximately 0.9 mile north of State Highway 107 and 0.5 mile west of Farm-to Market Road 1423, in the community of San Carlos, Hidalgo County, Texas 78542.

North Alamo Water Supply Corporation has applied to the Texas Commission on Environmental Quality (TCEQ) to renew the permit that authorizes the disposal of treated domestic wastewater effluent at a daily average flow not to exceed 0.210 million gallons per day (MGD) via surface irrigation of 56 acres of non-public access land. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain coliform bacteria, total suspended solids, ammonia nitrogen, nitrate nitrogen, total Kjeldahl nitrogen, sulfate, chloride, total phosphorous, total dissolved solids, oil and grease. Domestic wastewater will be treated by a facultative waste stabilization pond system.