

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Rosebud-Lott ISD (CN600639934) operates Rosebud-Lott Elementary School RN101194082. a subsurface area drip disposal system . The facility is located at 1789 U.S. Hwy. 77, in Lott, Tx, Falls County, Texas 76656.

This application is for a renewal to dispose of treated wastewater at a volume not to exceed a daily average of 9,900 gallons per day via public access surface irrigation with a minimum area of 2.7 acres. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain one-week biochemical oxygen demand (BOD₅), total suspended solids (TSS), and one-month *Escherichia coli*. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a lift station, EQ Basin, two (2) aeration basins, , a hopper style clarifier, and two (2) pump stations. The activated sludge is treated by *the aerobic digester and then removed from the system before being discharged from the plant.*