



Administrative Package Cover Page

This file contains the following documents:

1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
2. First Notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
3. Application materials



Portada de Paquete Administrativo

Este archivo contiene los siguientes documentos:

1. Resumen en lenguaje sencillo (PLS, por sus siglas en inglés) de la actividad propuesta
 - Inglés
 - Idioma alternativo (español)
2. Primer aviso (NORI, por sus siglas en inglés)
 - Inglés
 - Idioma alternativo (español)
3. Solicitud original

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Aqua Texas, Inc. (CN604062463) operates Leander Hills Wastewater Treatment Facility RN101702140, a domestic wastewater treatment facility. The facility is located approximately 6.5 miles northwest of the intersection of Farm-to-Market Road 1431 and 2243 and 2.5 miles west of the intersection of Farm-to-Market Road 2243 and Round Mountain Road., in Leander, Travis County, Texas 78641.

Request for renewal of permit authorizing the disposal of 15,000 GPD of treated domestic wastewater. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain BOD(5). Domestic wastewater is treated by **Activated sludge facility operated in the extended aeration mode.**

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

Aqua Texas, Inc. (CN604062463) opera la Instalación de Tratamiento de Aguas Residuales de Leander Hills RN101702140. una instalación de tratamiento de aguas residuales domésticas. La instalación está ubicada aproximadamente a 6.5 millas al noroeste de la intersección de Farm-to-Market Road 1431 y 2243 y a 2.5 millas al oeste de la intersección de Farm-to-Market Road 2243 y Round Mountain Road, en Leander, Condado de Travis, Texas 78641.

Solicitud de renovación de permiso que autoriza la disposición de 15,000 GPD de aguas residuales domésticas tratadas. Este permiso no autorizará una descarga de contaminantes al agua del estado.

Se espera que las descargas de la instalación contengan BOD(5). Las aguas residuales domésticas se tratan mediante **una instalación de lodos activados que funciona en modo de aireación extendida.**

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT

PERMIT NO. WQ0013337001

APPLICATION. Aqua Texas, Inc., 1106 Clayton Lane, Suite 400W, Austin, Texas 78723, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Land Application Permit (TLAP) No. WQ0013337001 to authorize the disposal of treated wastewater effluent at a daily average flow not to exceed 15,000 gallons via subsurface soil absorption-disposal with a minimum area of 45,000 square feet non-public access. The domestic wastewater treatment facility and disposal area are located approximately 6.5 miles northwest of the intersection of Farm-to-Market Road 1431 and Farm-to-Market Road 2243, in Travis County, Texas 78641. TCEQ received this application on June 27, 2024. The permit application will be available for viewing and copying at Austin Public Library, Milwood Branch, 12500 Amherst Drive, Austin, in Travis County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tlap-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.989166,30.584166&level=18>

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tlap-applications>.

El aviso de idioma alternativo en español está disponible en

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tlap-applications>.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. **Notice of the Application and Preliminary Decision will be published and mailed to those who are on the county-wide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.**

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing.** A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.**

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at <https://www14.tceq.texas.gov/epic/eComment/>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Aqua Texas, Inc. at the address stated above or by calling Mr. Abel Bautista, Wastewater Compliance Coordinator, at 281-651-0174, Extension 54119.

Issuance Date: July 22, 2024

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0013337001

SOLICITUD. Aqua Texas, Inc., 1106 Clayton Lane, Suite 400W, Austin, Texas 78723, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso para la Aplicación en Terrenos de Texas (TLAP) No. WQ0013337001 para autorizar la disposición de efluente de aguas residuales tratadas en un flujo promedio diario que no exceda 15,000 galones mediante la absorción y eliminación del suelo subterráneo con un área mínima de 45,000 pies cuadrados de acceso no público. La instalación de tratamiento de aguas residuales domésticas y el sitio de disposición están ubicados aproximadamente 6.5 millas al noroeste de la intersección de Farm-to-Market Road 1431 y Farm-to-Market Road 2243, en el Condado de Travis, Texas 78641. La TCEQ recibió esta solicitud el 27 de junio de 2024. La solicitud del permiso está disponible para leerla y copiarla en la Biblioteca Pública de Austin - Sucursal Milwood, 12500 Aherst Dr., Austin, TX 78727, antes de la fecha de publicación de este aviso en el periódico. La solicitud, incluidas las actualizaciones y los avisos asociados, están disponibles electrónicamente en la siguiente página web:

<https://www.tceq.texas.gov/permitting/wastewater/pendingpermits/tlap-applications>. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=97.989166,30.584166&level=18>

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas

designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía <http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional de Aqua Texas, Inc. a la dirección indicada arriba o llamando al Sr. Abel Bautista, Coordinador de Cumplimiento de Aguas Residuales, al 281-651-0174.

Fecha de emisión: 22 de julio de 2024



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
**DOMESTIC WASTEWATER PERMIT APPLICATION
 CHECKLIST**

Complete and submit this checklist with the application.

APPLICANT: Aqua Texas, Inc.

PERMIT NUMBER: WQ0013337001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Original USGS Map	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Administrative Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Affected Landowners Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
SPIF	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Landowner Disk or Labels	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Core Data Form	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Buffer Zone Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Public Involvement Plan Form	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Flow Diagram	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site Drawing	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Original Photographs	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Design Calculations	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solids Management Plan	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Water Balance	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.3	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 4.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 5.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 6.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 7.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

For TCEQ Use Only

Segment Number _____ County _____
 Expiration Date _____ Region _____
 Permit Number _____



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
APPLICATION FOR A DOMESTIC WASTEWATER PERMIT
ADMINISTRATIVE REPORT 1.0

If you have questions about completing this form please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 29)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 <input type="checkbox"/>	\$315.00 <input type="checkbox"/>
≥0.05 but <0.10 MGD	\$550.00 <input type="checkbox"/>	\$515.00 <input checked="" type="checkbox"/>
≥0.10 but <0.25 MGD	\$850.00 <input type="checkbox"/>	\$815.00 <input type="checkbox"/>
≥0.25 but <0.50 MGD	\$1,250.00 <input type="checkbox"/>	\$1,215.00 <input type="checkbox"/>
≥0.50 but <1.0 MGD	\$1,650.00 <input type="checkbox"/>	\$1,615.00 <input type="checkbox"/>
≥1.0 MGD	\$2,050.00 <input type="checkbox"/>	\$2,015.00 <input type="checkbox"/>

Minor Amendment (for any flow) \$150.00

Payment Information:

Mailed Check/Money Order Number: _____
Check/Money Order Amount: _____
Name Printed on Check: _____

EPAY Voucher Number: 708694/707695

Copy of Payment Voucher enclosed? Yes

Section 2. Type of Application (Instructions Page 29)

- | | |
|---|---|
| <input type="checkbox"/> New TPDES | <input type="checkbox"/> New TLAP |
| <input type="checkbox"/> Major Amendment <i>with</i> Renewal | <input type="checkbox"/> Minor Amendment <i>with</i> Renewal |
| <input type="checkbox"/> Major Amendment <i>without</i> Renewal | <input type="checkbox"/> Minor Amendment <i>without</i> Renewal |
| <input checked="" type="checkbox"/> Renewal without changes | <input type="checkbox"/> Minor Modification of permit |

For amendments or modifications, describe the proposed changes: _____

For existing permits:

Permit Number: WQ0013337001
EPA I.D. (TPDES only): TX _____
Expiration Date: 12/1/2024

TCEQ ePay Voucher Receipt

Transaction Information	
Voucher Number:	708694
Trace Number:	582EA000613364
Date:	06/10/2024 08:00 AM
Payment Method:	CC - Authorization 0000029702
Voucher Amount:	\$500.00
Fee Type:	WW PERMIT - FACILITY WITH FLOW >= .05 & < .10 MGD - RENEWAL
ePay Actor:	SCOT FOLTZ
Payment Contact Information	
Name:	SCOT FOLTZ
Company:	AQUA TEXAS
Address:	1106 CLAYTON LN SUITE 400W, AUSTIN, TX 78723
Phone:	512-844-6475
Site Information	
Site Name:	LEANDER HILL WASTEWATER TREATMENT FACILITY
Site Location:	APPROX 6.5 MILES NW OF FM1431 AND 2243 AND 2.5 MILES W OF FM 2243 AND ROUND MT
Customer Information	
Customer Name:	AQUA TEXAS
Customer Address:	1106 CLAYTON LN SUITE 400W, AUSTIN, TX 78722
Other Information	
Program Area ID:	0013337001

TCEQ ePay Voucher Receipt

Transaction Information

Voucher Number:	708695
Trace Number:	582EA000613364
Date:	06/10/2024 08:00 AM
Payment Method:	CC - Authorization 0000029702
Voucher Amount:	\$15.00
Fee Type:	30 TAC 305.53B WQ RENEWAL NOTIFICATION FEE
ePay Actor:	SCOT FOLTZ

Payment Contact Information

Name:	SCOT FOTLZ
Company:	AQUA TEXAS
Address:	1106 CLAYTON LN SUITE 400W, AUSTIN, TX 78723
Phone:	512-844-6475

Section 3. Facility Owner (Applicant) and Co-Applciant Information (Instructions Page 29)

A. The owner of the facility must apply for the permit.

What is the Legal Name of the entity (applicant) applying for this permit?

Aqua Texas, Inc.

(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)

If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at <http://www15.tceq.texas.gov/crpub/>

CN: 604062463

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Craig Blanchette

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: President

B. Co-applciant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applciant applying for this permit?

N/A

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applciant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at:

<http://www15.tceq.texas.gov/crpub/>

CN: [REDACTED]

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix (Mr., Ms., Miss): [REDACTED]

First and Last Name: [REDACTED]

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: [REDACTED]

Provide a brief description of the need for a co-permittee: [REDACTED]

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0.

Attachment: D

Section 4. Application Contact Information (Instructions Page 30)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix (Mr., Ms., Miss): Ms

First and Last Name: Stephanie Landsman

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: [REDACTED]

Organization Name: Landsman Environmental LLC

Mailing Address: 9597 Jones Road #962

City, State, Zip Code: Jersey Village, TX 77065

Phone No.: 281-658-5899 Ext.: [REDACTED] Fax No.: [REDACTED]

E-mail Address: stephanie@landsmanenviro.com

Check one or both: Administrative Contact Technical Contact

B. Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Abel Bautista

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: Wastewater Compliance Coordinator

Organization Name: Aqua Texas, Inc.

Mailing Address: 19244 Ella Blvd.

City, State, Zip Code: Spring, TX 77388

Phone No.: 281-651-0174 Ext.: 54119 Fax No.: [REDACTED]

E-mail Address: abautista@aquaaamerica.com

Check one or both: Administrative Contact Technical Contact

Section 5. Permit Contact Information (Instructions Page 30)

Provide two names of individuals that can be contacted throughout the permit term.

A. Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Craig Blanchette

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: President

Organization Name: Aqua Texas, Inc.

Mailing Address: 1106 Clayton Lane Ste. 400W

City, State, Zip Code: Austin, TX 78723

Phone No.: 512-990-4400 Ext.: 56105 Fax No.: [REDACTED]

E-mail Address: clblanchette@aquaaamerica.com

B. Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Abel Bautista

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: Wastewater Compliance. Coordinator

Organization Name: Aqua Texas, Inc.

Mailing Address: 19244 Ella Blvd.

City, State, Zip Code: Spring, TX 77388

Phone No.: 281-651-0174 Ext.: 54119 Fax No.: [REDACTED]

E-mail Address: abautista@aquaaamerica.com

Section 6. Billing Information (Instructions Page 30)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Jose Loya

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: [REDACTED]

Organization Name: Aqua Texas, Inc.

Mailing Address: 1106 Clayton Lane Ste. 400W

City, State, Zip Code: Austin, TX 78723

Phone No.: 512-990-4400 Ext.: [REDACTED] Fax No.: [REDACTED]

E-mail Address: aquatexasAP@aquaaamerica.com

Section 7. DMR/MER Contact Information (Instructions Page 31)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (EPA 3320-1) or maintain Monthly Effluent Reports.

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Scot Foltz

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: Environmental Compliance Manager

Organization Name: Aqua Texas, Inc.

Mailing Address: 1106 Clayton Lane Ste. 400W

City, State, Zip Code: Austin, TX 78723

Phone No.: 512-990-4400 Ext.: 56101 Fax No.: [REDACTED]

E-mail Address: swfoltz@aquaamerica.com

DMR data is required to be submitted electronically. Create an account at:

<https://www.tceq.texas.gov/permitting/netdmr/netdmr.html>.

Section 8. Public Notice Information (Instructions Page 31)

A. Individual Publishing the Notices

Prefix (Mr., Ms., Miss): Ms.

First and Last Name: Stephanie Landsman

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: [REDACTED]

Organization Name: Landsman Environmental LLC

Mailing Address: 9597 Jones Road #962

City, State, Zip Code: Jersey Village, TX 77065

Phone No.: 2818-658-5899 Ext.: [REDACTED]

Fax No.: [REDACTED]

E-mail Address: stephanie@landsmanenviro.com

B. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package

Indicate by a check mark the preferred method for receiving the first notice and instructions:

E-mail Address

Fax

Regular Mail

C. Contact person to be listed in the Notices

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Abel Baustista

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: Wastewater Compliance Coordinator

Organization Name: Aqua Texas, Inc.

Phone No.: 281-651-0174 Ext.: 54119

E-mail: abautista@aquaamerica.com

D. Public Viewing Information

If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.

Public building name: Faulk Central Library

Location within the building: [REDACTED]

Physical Address of Building: 800 Guadalupe St.

City: Austin

County: Travis

Contact Name: [REDACTED]

Phone No.: 512-974-7400 Ext.: [REDACTED]

E. Bilingual Notice Requirements:

This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

Yes No

If no, publication of an alternative language notice is not required; skip to Section 9 below.

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

Yes No

3. Do the students at these schools attend a bilingual education program at another location?

Yes No

Phone No.: 512-990-4400

E-mail Address: swfoltz@aquaamerica.com

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: [Redacted]

F. Owner of sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant):

Prefix (Mr., Ms., Miss): N/A

First and Last Name: [Redacted]

Mailing Address: [Redacted]

City, State, Zip Code: [Redacted]

Phone No.: [Redacted] E-mail Address: [Redacted]

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: [Redacted]

Section 10. TPDES Discharge Information (Instructions Page 34)

A. Is the wastewater treatment facility location in the existing permit accurate?

Yes No

If no, or a new permit application, please give an accurate description:

[Redacted description box]

B. Are the point(s) of discharge and the discharge route(s) in the existing permit correct?

Yes No

If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:

[Redacted description box]

City nearest the outfall(s): [Redacted]

County in which the outfalls(s) is/are located: [Redacted]

Outfall Latitude: [Redacted] Longitude: [Redacted]

C. Is or will the treated wastewater discharge to a city, county, or state highway right-of-way, or a flood control district drainage ditch?

Yes No

If yes, indicate by a check mark if:

Authorization granted Authorization pending

For new and amendment applications, provide copies of letters that show proof of contact and the approval letter upon receipt.

Attachment: [REDACTED]

- D. For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge.

N/A

Section 11. TLAP Disposal Information (Instructions Page 36)

- A. For TLAPs, is the location of the effluent disposal site in the existing permit accurate?

Yes No

If no, or a new or amendment permit application, provide an accurate description of the disposal site location:

[REDACTED]

- B. City nearest the disposal site: Leander
C. County in which the disposal site is located: Travis
D. Disposal Site Latitude: 30.583611 Longitude: -97.9875
E. For TLAPs, describe the routing of effluent from the treatment facility to the disposal site:

The treated effluent is pumped to the low dosing pressure fields. The fields are immediately southeast of the treatment facility.

- F. For TLAPs, please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained:

Long Hollow Creek

Section 12. Miscellaneous Information (Instructions Page 37)

- A. Is the facility located on or does the treated effluent cross American Indian Land?

Yes No

B. If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?

Yes No Not Applicable

If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.

C. Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?

Yes No

If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application:

D. Do you owe any fees to the TCEQ?

Yes No

If yes, provide the following information:

Account number:

Amount past due:

E. Do you owe any penalties to the TCEQ?

Yes No

If yes, please provide the following information:

Enforcement order number:

Amount past due:

Section 13. Attachments (Instructions Page 38)

Indicate which attachments are included with the Administrative Report. Check all that apply:

- Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
- Original full-size USGS Topographic Map with the following information:
 - Applicant's property boundary

- Treatment facility boundary
 - Labeled point of discharge for each discharge point (TPDES only)
 - Highlighted discharge route for each discharge point (TPDES only)
 - Onsite sewage sludge disposal site (if applicable)
 - Effluent disposal site boundaries (TLAP only)
 - New and future construction (if applicable)
 - 1 mile radius information
 - 3 miles downstream information (TPDES only)
 - All ponds.
- Attachment 1 for Individuals as co-applicants
- Other Attachments. Please specify:

Section 14. Signature Page (Instructions Page 39)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: W00013337001

Applicant: Agua Texas, Inc.

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Craig L. Blanchette


Signatory title: President

Signature: *CR Blanchett* Date: 6/10/24
(Use blue ink)

Subscribed and Sworn to before me by the said Craig Blanchette
on this 10 day of June, 2024.
My commission expires on the 3 day of May, 2027.

Olivia Jones
Notary Public

Travis
County, Texas



[SEAL]

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Aqua Texas, Inc. (CN604062463) operates Leander Hills Wastewater Treatment Facility RN101702140. a domestic wastewater treatment facility. The facility is located approximately 6.5 miles northwest of the intersection of Farm-to-Market Road 1431 and 2243 and 2.5 miles west of the intersection of Farm-to-Market Road 2243 and Round Mountain Road., in Leander, Travis County, Texas 78641.

Request for renewal of permit authorizing the disposal of 15,000 GPD of treated domestic wastewater. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain BOD(5). Domestic wastewater is treated by **Activated sludge facility operated in the extended aeration mode.**

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

Aqua Texas, Inc. (CN604062463) opera la Instalación de Tratamiento de Aguas Residuales de Leander Hills RN101702140. una instalación de tratamiento de aguas residuales domésticas. La instalación está ubicada aproximadamente a 6.5 millas al noroeste de la intersección de Farm-to-Market Road 1431 y 2243 y a 2.5 millas al oeste de la intersección de Farm-to-Market Road 2243 y Round Mountain Road, en Leander, Condado de Travis, Texas 78641.

Solicitud de renovación de permiso que autoriza la disposición de 15,000 GPD de aguas residuales domésticas tratadas. Este permiso no autorizará una descarga de contaminantes al agua del estado.

Se espera que las descargas de la instalación contengan BOD(5). Las aguas residuales domésticas se tratan mediante **una instalación de lodos activados que funciona en modo de aireación extendida.**



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION

DOMESTIC TECHNICAL REPORT 1.0

The Following Is Required For All Applications

Renewal, New, And Amendment

Section 1. Permitted or Proposed Flows (Instructions Page 51)

A. Existing/Interim I Phase

Design Flow (MGD):

2-Hr Peak Flow (MGD): [Click here to enter text.](#)

Estimated construction start date: [Click here to enter text.](#)

Estimated waste disposal start date: [Click here to enter text.](#)

B. Interim II Phase

Design Flow (MGD): [Click here to enter text.](#)

2-Hr Peak Flow (MGD): [Click here to enter text.](#)

Estimated construction start date: [Click here to enter text.](#)

Estimated waste disposal start date: [Click here to enter text.](#)

C. Final Phase

Design Flow (MGD): .015

2-Hr Peak Flow (MGD): .060

Estimated construction start date: [Click here to enter text.](#)

Estimated waste disposal start date: [Click here to enter text.](#)

D. Current operating phase: Final

Provide the startup date of the facility: June 1989

Section 2. Treatment Process (Instructions Page 51)

A. Treatment process description

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed in the permit, a description of each phase must be provided.**
 Process description:

Activated sludge facility operated in the extended aeration mode. From the lift station the sewage will flow through a coarse bar screen to the aeration basin. The mixed liquor will then flow to the clarifier where solids will settle to the bottom of the basin and the clear water will flow over the weirs. The effluent will then flow into the chlorine contact chamber and then to the storage tank. From there the treated effluent will be pumped b a low pressure dosing system to the land application site via subsurface soil absorption. The settled solids in the clarifier will be either pumped to the digester or to the aeration basin.

Port or pipe diameter at the discharge point, in inches: 3

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) – Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Aeration	1	14' x 435 sf
Clarifier	1	13.5' x 452 cf
Digester	1	14.5' x 268 cf
Chlorine Contact Chamber	1	11.6' x 101 sf
Storage Tank	3	15000 gals

C. Process flow diagrams

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

Attachment: C

Section 3. Site Drawing (Instructions Page 52)

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: B

Provide the name and a description of the area served by the treatment facility.

Leander Hills

Section 4. Unbuilt Phases (Instructions Page 52)

Is the application for a renewal of a permit that contains an unbuilt phase or phases?

Yes

No

If yes, does the existing permit contain a phase that has not been constructed within five years of being authorized by the TCEQ?

Yes

No

If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases.

[REDACTED]

Section 5. Closure Plans (Instructions Page 53)

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

Yes No

If yes, was a closure plan submitted to the TCEQ?

Yes No

If yes, provide a brief description of the closure and the date of plan approval.

[REDACTED]

Section 6. Permit Specific Requirements (Instructions Page 53)

For applicants with an existing permit, check the *Other Requirements* or *Special Provisions* of the permit.

A. Summary transmittal

Have plans and specifications been approved for the existing facilities and each proposed phase?

Yes No

If yes, provide the date(s) of approval for each phase: July 1995

Provide information, including dates, on any actions taken to meet a requirement or provision pertaining to the submission of a summary transmittal letter. Provide a copy of an approval letter from the TCEQ, if applicable.

B. Buffer zones

Have the buffer zone requirements been met?

Yes No

Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.

C. Other actions required by the current permit

Does the *Other Requirements* or *Special Provisions* section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.

Yes No

If yes, provide information below on the status of any actions taken to meet the conditions of an *Other Requirement* or *Special Provision*.

D. Grit and grease treatment

1. Acceptance of grit and grease waste

Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?

Yes No

If No, stop here and continue with Subsection E. Stormwater Management.

2. *Grit and grease processing*

Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.

3. *Grit disposal*

Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?

Yes

No

If No, contact the TCEQ Municipal Solid Waste team at 512-239-0000. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

Describe the method of grit disposal.

4. *Grease and decanted liquid disposal*

Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-0000.

Describe how the decant and grease are treated and disposed of after grit separation.

E. Stormwater management

1. *Applicability*

Does the facility have a design flow of 1.0 MGD or greater in any phase?

Yes No

Does the facility have an approved pretreatment program, under 40 CFR Part 403?

Yes No

If no to both of the above, then skip to Subsection F, Other Wastes Received.

2. MSGP coverage

Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?

Yes No

If yes, please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:

TXR05 [redacted] or TXRNE [redacted]

If no, do you intend to seek coverage under TXR050000?

Yes No

3. Conditional exclusion

Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?

Yes No

If yes, please explain below then proceed to Subsection F, Other Wastes Received:

4. Existing coverage in individual permit

Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?

Yes No

If yes, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.

5. Zero stormwater discharge

Do you intend to have no discharge of stormwater via use of evaporation or other means?

Yes No

If yes, explain below then skip to Subsection F. Other Wastes Received.

Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.

6. Request for coverage in individual permit

Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?

Yes No

If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.

Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution

prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.

F. Discharges to the Lake Houston Watershed

Does the facility discharge in the Lake Houston watershed?

Yes No

If yes, a Sewage Sludge Solids Management Plan is required. See Example 5 in the instructions.

G. Other wastes received including sludge from other WWTPs and septic waste

1. Acceptance of sludge from other WWTPs

Does the facility accept or will it accept sludge from other treatment plants at the facility site?

Yes No

If yes, attach sewage sludge solids management plan. See Example 5 of the instructions.

In addition, provide the date that the plant started accepting sludge or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the sludge, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

2. Acceptance of septic waste

Is the facility accepting or will it accept septic waste?

Yes No

If yes, does the facility have a Type V processing unit?

Yes No

If yes, does the unit have a Municipal Solid Waste permit?

Yes No

If yes to any of the above, provide a the date that the plant started accepting septic waste, or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the septic waste, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)

Is the facility accepting or will it accept wastes that are not domestic in nature excluding the categories listed above?

Yes No

If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.

Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 58)

Is the facility in operation?

Yes No

If no, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. *Wastewater treatment facilities* complete Table 1.0(2). *Water treatment facilities* discharging filter backwash water, complete Table 1.0(3).

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/ Time
CBOD ₅ , mg/l	2.72		1	Grab	4/24/24;546
Total Suspended Solids, mg/l	6.42		1	Grab	4/24/24;546
Ammonia Nitrogen, mg/l	0.0910		1	Grab	4/24/24;546
Nitrate Nitrogen, mg/l	42.7		1	Grab	4/24/24;546
Total Kjeldahl Nitrogen, mg/l	<1.00		1	Grab	4/24/24;546
Sulfate, mg/l	68.2		1	Grab	4/24/24;546
Chloride, mg/l					
Total Phosphorus, mg/l	7.02		1	Grab	4/24/24;546
pH, standard units	7.04		1	Grab	4/24/24;546
Dissolved Oxygen*, mg/l	8.66		1	Grab	4/24/24;546
Chlorine Residual, mg/l	1.24		1	Grab	4/24/24;546
<i>E.coli</i> (CFU/100ml) freshwater	<1.00		1	Grab	4/24/24;546
Enterococci (CFU/100ml) saltwater	N/A				
Total Dissolved Solids, mg/l	714		1	Grab	4/24/24;546
Electrical Conductivity, μ mohs/cm, †	1080		1	Grab	4/24/24;546
Oil & Grease, mg/l	<5.00		1	Grab	4/24/24;546
Alkalinity (CaCO ₃)*, mg/l	N/A				

*TPDES permits only

†TLAP permits only

Table 1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/ Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l					
pH, standard units					



Aqua TX
 2211 Louetta Road
 Spring, TX 77388


Reported:
 05/08/2024 12:32

Sample Results

Client Sample ID: Outfall 001 Sample Matrix: Waste Water
 Lab Sample ID: 24D5292-01 Date Collected: 04/24/2024 5:46
 Leander Hills - Non Potable - Permit Renew Aqua TX Lean Collected by: Cesar Guevara

Method	Analyte	*	Result Q	Units	DF	SDL	LRL	Batch	Analyzed	Analyst
General Chemistry										
SM 2320 B	Alkalinity as CaCO3	A	101	mg/L	1	10.0	10.0	BHD4352	04/25/2024 14:38	AKA
SM 5210 B	Biochemical Oxygen Demand (BOD)	A	3.20FF	mg/L	113514	2.03	2.03	BHD4388	04/30/2024 08:52	BAK
SM 5210 B	Carbonaceous BOD (CBOD)	A	2.72	mg/L	113514	2.03	2.03	BHD4391	04/30/2024 09:00	BAK
SM 2510 B	Conductivity	A	1080	umhos/cm @ 25 °C	1	2.00	2.00	BHD4352	04/25/2024 14:38	AKA
EPA 350.1	Ammonia as N	A	0.0910	mg/L	1	0.0200	0.0500	BHD4511	04/30/2024 11:45	NAZ
EPA 300.0	Nitrate as N	A	42.7	mg/L	20	0.284	2.00	BHD4289	04/25/2024 04:55	ORP
EPA 1664A	n-Hexane Extractable Material (O&G)	A	<5.00U	mg/L	1	5.00	5.00	BHE0479	05/03/2024 09:34	IDC
EPA 300.0	Sulfate	A	68.2	mg/L	20	0.682	20.0	BHD4289	04/25/2024 04:55	ORP
SM 2540 C	Residue-filterable (TDS)	A	714	mg/L	1	10.0	10.0	BHD4344	04/26/2024 15:22	JRU
SM 4500-NH3 C	Total Kjeldahl Nitrogen - (TKN)	A	<1.00U	mg/L	1	0.100	1.00	BHD4743	04/29/2024 12:21	GIW
EPA 365.1	Total Phosphorus	A	7.02	mg/L	1	0.117	0.200	BHD4471	04/26/2024 09:01	TBB
SM 2540 D	Residue-nonfilterable (TSS)	A	6.42	mg/L	1	1.00	1.00	BHD4368	04/26/2024 10:07	BP
Field										
Hach 10360	DO Field	N	8.66	mg/L	1	1.00	1.00	BHD4322	04/24/2024 05:46	CGJ
Calc	Flow Field	N	0.00349	MGD	1	0.00	0.00	BHD4322	04/24/2024 05:46	CGJ
SM 4500-H+ B	pH	A	7.04	pH Units @ 25 °C	1	1.00	1.00	BHD4322	04/24/2024 05:46	CGJ

* A = Accredited, N = Not Accredited or Accreditation not available



Aqua TX
 2211 Louetta Road
 Spring, TX 77388

Reported:
 05/08/2024 12:32

Sample Results
 (Continued)

Client Sample ID: Outfall 001 Sample Matrix: Waste Water
 Lab Sample ID: 24E1327-01 Date Collected: 05/01/2024 9:00
 Leander Hills - Permit Renewal - Recollect Aqua TX Lean Collected by: Francisco Gutierrez

Method	Analyte	*	Result Q	Units	DF	SDL	LRL	Batch	Analyzed	Analyst
Microbiology										
SM 9223 B (Colilert Quanti-Tray)	Escherichia coli (E. coli)	A	<1.00U	MPN/100 mL	1	1.00	1.00	BHE0226	05/02/2024 16:54	JKB
Field										
SM 4500-Cl G	Total Residual Chlorine	A	1.24	mg/L	1	0.25	0.25	BHE0346	05/01/2024 09:00	FG

* A = Accredited, N = Not Accredited or Accreditation not available

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/ Time
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 60)

Facility Operator Name: Larry Strawther

Facility Operator's License Classification and Level: WW:"B"

Facility Operator's License Number: WW008139

Section 9. Sewage Sludge Management and Disposal (Instructions Page 60)

A. Sludge disposal method

Identify the current or anticipated sludge disposal method or methods from the following list. Check all that apply.

- Permitted landfill
- Permitted or Registered land application site for beneficial use
- Land application for beneficial use authorized in the wastewater permit
- Permitted sludge processing facility
- Marketing and distribution as authorized in the wastewater permit
- Composting as authorized in the wastewater permit
- Permitted surface disposal site (sludge monofill)
- Surface disposal site (sludge monofill) authorized in the wastewater permit
- Transported to another permitted wastewater treatment plant or permitted sludge processing facility. If you selected this method, a written statement or contractual agreement from the wastewater treatment plant or permitted sludge processing facility accepting the sludge must be included with this application.
- Other:

B. Sludge disposal site

Disposal site name: Austin WW Processing Facility

TCEQ permit or registration number: WQ0002384000

County where disposal site is located: Travis

C. Sludge transportation method

Method of transportation (truck, train, pipe, other): truck

Name of the hauler: Wastewater Residuals Management LLC

Hauler registration number: 24343

Sludge is transported as a:

Liquid semi-liquid semi-solid solid

Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 60)

A. Beneficial use authorization

Does the existing permit include authorization for land application of sewage sludge for beneficial use?

Yes No

If yes, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

Yes No

If yes, is the completed **Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)** attached to this permit application (see the instructions for details)?

Yes No

B. Sludge processing authorization

Does the existing permit include authorization for any of the following sludge processing, storage or disposal options?

Sludge Composting Yes No

Marketing and Distribution of sludge Yes No

Sludge Surface Disposal or Sludge Monofill Yes No

Temporary storage in sludge lagoons Yes No

If yes to any of the above sludge options and the applicant is requesting to continue this authorization, is the completed **Domestic Wastewater Permit Application: Sewage Sludge**

Technical Report (TCEQ Form No. 10056) attached to this permit application?

Yes No

Section 11. Sewage Sludge Lagoons (Instructions Page 61)

Does this facility include sewage sludge lagoons?

Yes No

If yes, complete the remainder of this section. If no, proceed to Section 12.

A. Location information

The following maps are required to be submitted as part of the application. For each map, provide the Attachment Number.

- Original General Highway (County) Map:

Attachment: [REDACTED]

- USDA Natural Resources Conservation Service Soil Map:

Attachment: [REDACTED]

- Federal Emergency Management Map:

Attachment: [REDACTED]

- Site map:


Attachment: [REDACTED]

Discuss in a description if any of the following exist within the lagoon area. Check all that apply.

- Overlap a designated 100-year frequency flood plain
- Soils with flooding classification
- Overlap an unstable area
- Wetlands
- Located less than 60 meters from a fault
- None of the above

Attachment: [REDACTED]

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:



B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in Section 7 of Technical Report 1.0.

- Nitrate Nitrogen, mg/kg: [redacted]
- Total Kjeldahl Nitrogen, mg/kg: [redacted]
- Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: [redacted]
- Phosphorus, mg/kg: [redacted]
- Potassium, mg/kg: [redacted]
- pH, standard units: [redacted]
- Ammonia Nitrogen mg/kg: [redacted]
- Arsenic: [redacted]
- Cadmium: [redacted]
- Chromium: [redacted]
- Copper: [redacted]
- Lead: [redacted]
- Mercury: [redacted]
- Molybdenum: [redacted]
- Nickel: [redacted]
- Selenium: [redacted]
- Zinc: [redacted]
- Total PCBs: [redacted]

Provide the following information:

- Volume and frequency of sludge to the lagoon(s): [redacted]
- Total dry tons stored in the lagoons(s) per 365-day period: [redacted]
- Total dry tons stored in the lagoons(s) over the life of the unit: [redacted]

C. Liner information

Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity

of 1×10^{-7} cm/sec?

Yes No

If yes, describe the liner below. Please note that a liner is required.

D. Site development plan

Provide a detailed description of the methods used to deposit sludge in the lagoon(s):

Attach the following documents to the application.

- Plan view and cross-section of the sludge lagoon(s)
Attachment: [REDACTED]
- Copy of the closure plan
Attachment: [REDACTED]
- Copy of deed recordation for the site
Attachment: [REDACTED]
- Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
Attachment: [REDACTED]
- Description of the method of controlling infiltration of groundwater and surface water from entering the site
Attachment: [REDACTED]
- Procedures to prevent the occurrence of nuisance conditions
Attachment: [REDACTED]

E. Groundwater monitoring

Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?

Yes No

If groundwater monitoring data are available, provide a copy. Provide a profile of soil types

encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.

Attachment: [REDACTED]

Section 12. Authorizations/Compliance/Enforcement (Instructions Page 63)

A. Additional authorizations

Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?

Yes No

If yes, provide the TCEQ authorization number and description of the authorization:

[REDACTED]

B. Permittee enforcement status

Is the permittee currently under enforcement for this facility?

Yes No

Is the permittee required to meet an implementation schedule for compliance or enforcement?

Yes No

If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:

[REDACTED]

Section 13. RCRA/CERCLA Wastes (Instructions Page 63)

A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

Yes No

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive


CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

Yes No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment:



Section 14. Laboratory Accreditation (Instructions Page 64)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - periodically inspected by the TCEQ; or
 - located in another state and is accredited or inspected by that state; or
 - performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review *30 TAC Chapter 25* for specific requirements.


The following certification statement shall be signed and submitted with every application. See the *Signature Page* section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*.

Printed Name: Craig Blanchette

Title: President

Signature: 

Date: 6/10/24

DOMESTIC WORKSHEET 3.0

LAND DISPOSAL OF EFFLUENT

**The following is required for all permit applications
Renewal, New, and Amendments**

Section 1. Type of Disposal System (Instructions Page 77)

Identify the method of land disposal:

- | | |
|---|--|
| <input type="checkbox"/> Surface application
<input type="checkbox"/> Irrigation
<input type="checkbox"/> Drip irrigation system
<input type="checkbox"/> Evaporation
<input type="checkbox"/> Evapotranspiration beds
<input type="checkbox"/> Other (describe in detail): Click here to enter text | <input type="checkbox"/> Subsurface application
<input checked="" type="checkbox"/> Subsurface soils absorption
<input type="checkbox"/> Subsurface area drip dispersal system |
|---|--|

NOTE: All applicants without authorization or proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0.

For existing authorizations, provide Registration Number: [Click here to enter text](#)

Section 2. Land Application Site(s) (Instructions Page 77)

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

Table 3.0(1) – Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N
Grass	1.03	15000	N

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

Section 3. Storage and Evaporation Lagoons/Ponds (Instructions Page 77)

Table 3.0(2) – Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type
N/A				

Attach a copy of a liner certification that was prepared, signed, and sealed by a Texas licensed professional engineer for each pond.

Attachment: [Click here to enter text](#)

Section 4. Flood and Runoff Protection (Instructions Page 77)

Is the land application site within the 100-year frequency flood level?

Yes No

If yes, describe how the site will be protected from inundation.

[Click here to enter text](#)

Provide the source used to determine the 100-year frequency flood level:

FEMA

Provide a description of tailwater controls and rainfall run-on controls used for the land application site.

The irrigation site has diversion berms and sloped ground to control rainfall runoff.

Section 5. Annual Cropping Plan (Instructions Page 77)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why.

Attachment: [REDACTED]

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

Section 6. Well and Map Information (Instructions Page 78)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation (on a separate page) indicating why.

Attachment: [REDACTED]

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)
- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities

- All water wells within 1 mile of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) – Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
2270054	Water Supply	Y	cased	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment: [Click here to enter text](#)

Section 7. Groundwater Quality (Instructions Page 79)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners. Indicate by a check mark that this report is provided.

Attachment: [Click here to enter text](#)

Are groundwater monitoring wells available onsite? Yes No

Do you plan to install ground water monitoring wells or lysimeters around the land application

site? Yes No

If yes, then provide the proposed location of the monitoring wells or lysimeters on a site map.

Attachment: [Click here to enter text](#)

Section 8. Soil Map and Soil Analyses (Instructions Page 79)

A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment: E

B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note:** for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

Attachment: E

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

Table 3.0(4) – Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number
VoD	54"		High	

Section 9. Effluent Monitoring Data (Instructions Page 80)

Is the facility in operation?

Yes No

If no, this section is not applicable and the worksheet is complete.

If yes, provide the effluent monitoring data for the parameters regulated in the existing permit. If a parameter is not regulated in the existing permit, enter N/A.

Table 3.0(5) – Effluent Monitoring Data

Date	30 Day Avg Flow MGD	BOD5 mg/l	TSS mg/l	pH	Chlorine Residual mg/l	Acres irrigated
10/22	.0199	3.53	N/A	7.53	N/A	1.03
11/22	.0178	3.28	N/A	7.39	N/A	1.03
12/22	.0020	2.17	N/A	7.40	N/A	1.03
1/23	.0109	<2.03	N/A	7.77	N/A	1.03
2/23	.0093	<2.03	N/A	7.53	N/A	1.03
3/23	.0057	2.17	N/A	6.79	N/A	1.03
4/23	.0076	2.51	N/A	7.14	N/A	1.03
5/23	.0140	<2.03	N/A	7.35	N/A	1.03
6/23	.0093	2.89	N/A	7.12	N/A	1.03
7/23	.0127	2.87	N/A	7.14	N/A	1.03
8/23	.0044	<2.03	N/A	7.18	N/A	1.03
9/23	.0060	2.05	N/A	7.12	N/A	1.03
10/23	.0030	2.59	N/A	7.3	N/A	1.03
11/23	.0024	3.84	N/A	7.25	N/A	1.03
12/23	.0073	<2.03	N/A	7.23	N/A	1.03
1/24	.0055	2.81	N/A	7.02	N/A	1.03
2/24	.0035	3.51	N/A	7.53	N/A	1.03
3/24	.0035	3.70	N/A	7.16	N/A	1.03
4/24	.0035	2.96	N/A	7.08	N/A	1.03

Attachment Index

Attachment



Title


A	Original USGS Topographic Map
B	Site Drawing
C	Flow Diagram
D	Core Data Form
E	Soil Map & Analyses
F	Sludge Hauling Letter

Attachment A

Original USGS Topographic Map

SCALE 1:24 000





55 DR

TRAVIS CO

Cottonwood Br

COW CREEK RD

Bee Cr.


Post Oak Ridge

Giltum Hollow

1 mi. radius

Attachment B


Site Drawing




Aqua Texas, INC
WQ0013337001
April 2024



ATTACHMENT A



CONTOUR INTERVAL 20 FEET
NATIONAL GEODETIC VERTICAL DATUM OF 1929




UTM GRID AND 1986 MAGNETIC NORTH DECLINATION AT CENTER OF MAP DIAGRAM IS APPROXIMATE

Attachment C

Flow Diagram

Leander Hills WWTP – TPDES Permit No. 13337-001
EXISTING and FINAL Phase - Flow Diagram



Attachment D

Core Data Form



TCEQ Use Only

TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)	
<input type="checkbox"/> New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)	
<input checked="" type="checkbox"/> Renewal (Core Data Form should be submitted with the renewal form)	<input type="checkbox"/> Other
2. Customer Reference Number (if issued)	3. Regulated Entity Reference Number (if issued)
CN 604062463	RN 101702140

SECTION II: Customer Information

4. General Customer Information		5. Effective Date for Customer Information Updates (mm/dd/yyyy)	
<input type="checkbox"/> New Customer		<input type="checkbox"/> Update to Customer Information	
<input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)		<input type="checkbox"/> Change in Regulated Entity Ownership	
<i>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</i>			
6. Customer Legal Name (If an individual, print last name first: eg: Doe, John)		If new Customer, enter previous Customer below:	
Aqua Texas, Inc.			
7. TX SOS/CPA Filing Number	8. TX State Tax ID (11 digits)	9. Federal Tax ID (9 digits)	10. DUNS Number (if applicable)
0800304878	32014405503		
11. Type of Customer:	<input checked="" type="checkbox"/> Corporation	<input type="checkbox"/> Individual	Partnership: <input type="checkbox"/> General <input type="checkbox"/> Limited
Government: <input type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> Local <input type="checkbox"/> State <input type="checkbox"/> Other	<input type="checkbox"/> Sole Proprietorship	<input type="checkbox"/> Other:	
12. Number of Employees	13. Independently Owned and Operated?		
<input type="checkbox"/> 0-20 <input type="checkbox"/> 21-100 <input checked="" type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
14. Customer Role (Proposed or Actual) – as it relates to the Regulated Entity listed on this form. Please check one of the following			
<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input checked="" type="checkbox"/> Owner & Operator <input type="checkbox"/> Other:			
<input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> VCP/BSA Applicant			
15. Mailing Address:	1106 Clayton Lane Ste. 400W		
City	Austin	State	TX
ZIP	78723	ZIP + 4	
16. Country Mailing Information (if outside USA)		17. E-Mail Address (if applicable)	
		aboutista@aquaamerica.com	
18. Telephone Number	19. Extension or Code	20. Fax Number (if applicable)	
(281) 651-0174	54119	() -	

SECTION III: Regulated Entity Information

21. General Regulated Entity Information (If "New Regulated Entity" is selected, a new permit application is also required.)
<input type="checkbox"/> New Regulated Entity <input type="checkbox"/> Update to Regulated Entity Name <input type="checkbox"/> Update to Regulated Entity Information
<i>The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).</i>
22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)
Leander Hills Wastewater Treatment Facility

23. Street Address of the Regulated Entity: (No PO Boxes)							
	City		State		ZIP		ZIP + 4
24. County	Travis						

If no Street Address is provided, fields 25-28 are required.

25. Description to Physical Location:	located approximately 6.5 miles northwest of the intersection of Farm-to-Market Road 1431 and 2243 and 2.5 miles west of the intersection of Farm-to-Market Road 2243 and Round Mountain Road.					
26. Nearest City	State			Nearest ZIP Code		
Leander	TX			78641		
Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).						
27. Latitude (N) In Decimal:	30.584384			28. Longitude (W) In Decimal:	-97.989451	
Degrees	Minutes	Seconds	Degrees	Minutes	Seconds	
29. Primary SIC Code (4 digits)	30. Secondary SIC Code (4 digits)		31. Primary NAICS Code (5 or 6 digits)		32. Secondary NAICS Code (5 or 6 digits)	
4952			22132			
33. What is the Primary Business of this entity? (Do not repeat the SIC or NAICS description.)						
Water and Wastewater Service Provider						
34. Mailing Address:	1106 Clayton Lane Ste. 400W					
	City	Austin	State	TX	ZIP	78723
35. E-Mail Address:	aboutista@aquaaamerica.com					
36. Telephone Number	37. Extension or Code		38. Fax Number (if applicable)			
(281) 651-174	54119		() -			

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input type="checkbox"/> PWS
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input checked="" type="checkbox"/> Wastewater	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:
	WQ0013337001			

SECTION IV: Preparer Information

40. Name:	Stephanie Landsman	41. Title:	Wastewater Specialist
42. Telephone Number	43. Ext./Code	44. Fax Number	45. E-Mail Address
(281) 658-5899		() -	stephanie@landsmanenviro.com

SECTION V: Authorized Signature

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.


Company:	Aqua Texas, Inc.	Job Title:	President
Name (In Print):	Craig L. Blanchette	Phone:	(512) 990-4400
Signature:		Date:	6/10/24

Attachment E


Soil Map and Analyses

LEANDER HILLS WWTP

Soil Map—Travis County, Texas



Map Scale: 1:2,400 if printed on A landscape (11" x 8.5") sheet.



Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 14N WGS84



Natural Resources
Conservation Service

Web Soil Survey
National Cooperative Soil Survey

5/22/2014
Page 1 of 3

MAP LEGEND

Area of Interest (AOI)

 Area of Interest (AOI)

Soils

 Soil Map Unit Polygons

 Soil Map Unit Lines

 Soil Map Unit Points

Special Point Features

 Blowout

 Borrow Pit

 Clay Spot

 Closed Depression

 Gravel Pit

 Gravelly Spot

 Landfill

 Lava Flow

 Marsh or swamp

 Mine or Quarry

 Miscellaneous Water

 Perennial Water

 Rock Outcrop

 Saline Spot

 Sandy Spot

 Severely Eroded Spot

 Sinkhole

 Slide or Slip

 Sodic Spot

 Spoil Area

 Stony Spot

 Very Stony Spot

 Wet Spot

 Other

 Special Line Features

Water Features

 Streams and Canals

Transportation

 Rails

 Interstate Highways

 US Routes

 Major Roads

 Local Roads

Background

 Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service
 Web Soil Survey URL: <http://websoilsurvey.nrcs.usda.gov>
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Travis County, Texas
 Survey Area Data: Version 14, Dec 12, 2013

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Feb 18, 2010—Apr 18, 2011

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Map Unit Legend

Travis County, Texas (TX453)			
Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
BID	Brackett-Rock outcrop complex, 1 to 12 percent slopes	0.0	0.0%
BoF	Brackett-Rock outcrop-Real complex, 8 to 30 percent slopes	4.4	17.3%
LcB	Lewisville silty clay, 1 to 2 percent slopes	7.4	29.0%
Md	Mixed alluvial land, 0 to 1 percent slopes, frequently flooded	5.6	21.7%
VoD	Volente silty clay loam, 1 to 8 percent slopes	8.2	31.9%
Totals for Area of Interest		25.7	100.0%



Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087
MONTHLY EFFLUENT REPORT

WQ0013337001
PERMIT NUMBER

31747
SET

2023	9
YEAR	MO

Leander Hills
EID

This report to be used for SOIL MON 301 ANN 18-30"
Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
<i>EXAMPLE</i> 4006080	Permitted	<i>permitted #</i>	<i>Std Units</i>		<i>1/year</i>	<i>24-hour comp</i>
<i>pH Maximum</i>	Reported	<i>result</i>	<i>units</i>	<i>#</i>		
6651430- Total Phosphorus	Permitted					
	Reported	19	ppm	0	1/year	comp
9371430- Potassium, Total	Permitted					
	Reported	369	ppm	0	1/year	comp
6001430- Total Nitrogen as N	Permitted					
	Reported	2474	mg/kg	0	1/year	comp
9504280- Conductivity Specific	Permitted					
	Reported	297	umho/cm	0	1/year	comp
6251430- Total Kjedahl Nitrogen	Permitted					
	Reported	1350	mg/kg	0	1/year	comp
4006080- pH	Permitted					
	Reported	8.2	S.U.	0	1/year	comp
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Leonel Cruz		10	19	2023
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Brent Reeh		10	19	2023
Telephone Number		512	330	9904
		Area code		Number



Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087
MONTHLY EFFLUENT REPORT

WQ0013337001
PERMIT NUMBER

31747
SET

2023	9
YEAR	MO

Leander Hills
EID

This report to be used for SOIL MON 201 ANN 6-18"
Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
<i>EXAMPLE</i> 4006080 pH Maximum	Permitted	<i>permitted #</i>	<i>Std Units</i>		<i>1/year</i>	<i>24-hour comp</i>
	Reported	<i>result</i>	<i>units</i>	<i>#</i>		
6651430- Total Phosphorus	Permitted					
	Reported	15	ppm	0	1/year	comp
9371430- Potassium, Total	Permitted					
	Reported	330	ppm	0	1/year	comp
6001430- Total Nitrogen as N	Permitted					
	Reported	2098	mg/kg	0	1/year	comp
9504280- Conductivity Specific	Permitted					
	Reported	156	umho/cm	0	1/year	comp
6251430- Total Kjedahl Nitrogen	Permitted					
	Reported	958	mg/kg	0	1/year	comp
4006080- pH	Permitted					
	Reported	8.2	S.U.	0	1/year	comp
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Leonel Cruz	<i>[Signature]</i>	10	19	2023
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Brent Reeh	<i>Brent C. Reeh</i>	10	19	2023
Telephone Number		512	330	9904
		Area code		Number



Texas Commission on Environmental Quality

P.O. Box 13087 • Austin, TX 78711-3087
MONTHLY EFFLUENT REPORT

WQ0013337001
PERMIT NUMBER

31747
SET

2023	9
YEAR	MO

Leander Hills
EID

This report to be used for SOIL MON 101 ANN 0-6"
Please retain a photocopy for your records.

Parameter Code/ Parameter	Effluent Condition			No. Ex	Frequency of Analysis	Sample Type
		Value	Units			
<i>EXAMPLE</i>	Permitted	<i>permitted #</i>	<i>Std Units</i>		<i>1/year</i>	<i>24-hour comp</i>
4006080 pH Maximum	Reported	<i>result</i>	<i>units</i>	<i>#</i>		
6651430- Total Phosphorus	Permitted					
	Reported	22	ppm	0	1/year	comp
9371430- Potassium, Total	Permitted					
	Reported	395	ppm	0	1/year	comp
6001430- Total Nitrogen as N	Permitted					
	Reported	2234	mg/kg	0	1/year	comp
9504280- Conductivity Specific	Permitted					
	Reported	134	umho/cm	0	1/year	comp
6251430- Total Kjedahl Nitrogen	Permitted					
	Reported	1290	mg/kg	0	1/year	comp
4006080- pH	Permitted					
	Reported	8.1	S.U.	0	1/year	comp
	Permitted					
	Reported					
	Permitted					
	Reported					
	Permitted					
	Reported					

COMMENTS AND EXPLANATIONS (Reference all attachments here.)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE.

PLANT OPERATOR NAME	PLANT OPERATOR SIGNATURE	MONTH	DAY	YEAR
Leonel Cruz	<i>[Signature]</i>	10	19	2023
EXECUTIVE OFFICER NAME	EXECUTIVE OFFICER SIGNATURE	MONTH	DAY	YEAR
Brent Reeh	<i>Brent C. Reeh</i>	10	19	2023
Telephone Number		512	330	9904
		Area code	Number	

Email information for report date:
10/18/23 12:48
G031747

Aqua-Texas, Inc.

Attn: Brent Reeh

3209 Hillbilly Ln
Austin, TX 78746

August 2023 price increase.

Due to the increase in operational costs, Aqua-Tech Laboratories will be implementing a slight price increase. The new price list will be effective August 1, 2023.

Aqua-Tech values you as a customer and encourages you to reach out to our accounting staff at accounting@aquatechlabs.com if you have questions.

Thank you for your business,
June M. Brien
Executive Technical Director

BRYAN FACILITY
635 Phil Gramm Boulevard
Bryan, TX 77807
Phone: (979) 778-3707
Fax: (979) 778-3193



AUSTIN FACILITY
3512 Montopolis Dr. Suite A
Austin, TX 78744
Phone: (512) 301-9559
Fax: (512) 301-9552

The analyses summarized in this report were performed by Aqua-Tech Laboratories, Inc. unless otherwise noted. Aqua-Tech Laboratories, Inc. holds accreditation from the State of Texas in accordance with TNI and/or through the TCEQ Drinking Water Commercial Laboratory Approval Program.

The following abbreviations indicate certification status:

- NEL TNI accredited parameter.
- ANR Accreditation not offered by the State of Texas.
- DWP Approval through the TCEQ Drinking Water Commercial Laboratory Approval Program.
- INF Aqua-Tech Laboratories, Inc. is not accredited for this parameter. It is reported on an informational basis only.

Certificate: T104704371-22-26



TCEQ Lab ID T104704371

Subcontracted data summarized in this report is indicated by "Sub" in the Lab column.

General Definitions:

- NR Not Reported.
- RPD Relative Percent Difference.
- % R Percent Recovery.
- dry Results with the "dry" unit designation are reported on a "dry weight" basis.
- SQL The Sample Quantitation Limit is the value below which the parameter cannot reliably be detected. The SQL includes all sample preparations, dilutions and / or concentrations.
- Adj MDL The Adjusted Method Detection Limit is the MDL value adjusted for any sample dilutions or concentrations.
- MDL The Method Detection Limit is the lowest theoretical value that is statistically different from zero for a specific method, taking into account all preparation steps and instrument settings.

All samples are reported on an "as received" basis unless the designation "dry" is added to the reported unit.

Copies of Aqua-Tech Laboratories, Inc. procedures and individual sampling plans are available upon request. Note that samples are collected by Aqua-Tech Laboratories, Inc. personnel unless otherwise noted in the "Sample Collected" field of this report as "Client" or "CLT".

Samples included in this report were received in acceptable condition according to Aqua-Tech Laboratories, Inc. procedures and 40 CFR, Chapter I, Subchapter D, Part 136.3, TABLE II. - *Required containers, preservation techniques, and holding times*, unless otherwise noted in this report.

Record Retention:

All reports, raw data, and associated quality control data are kept on file for 10 years before being destroyed. Any client that would like copies of records must contact Aqua-Tech Laboratories, Inc. no later than six months prior to the scheduled disposal. An administrative fee for retrieval and distribution will apply.

This report was approved by:

June M. Brien, Technical Director

The results in this report apply only to the samples analyzed. This analytical report must be reproduced in its entirety unless written permission is granted by Aqua-Tech Laboratories, Inc.

corp@aquatechlabs.com

www.aquatechlabs.com

BRYAN FACILITY
 635 Phil Gramm Boulevard
 Bryan, TX 77807
 Phone: (979) 778-3707
 Fax: (979) 778-3193



AUSTIN FACILITY
 3512 Montopolis Dr. Suite A
 Austin, TX 78744
 Phone: (512) 301-9559
 Fax: (512) 301-9552

Analytical Report

Report Printed: 10/18/23 12:48
 Aqua-Texas, Inc.
 G031747

See attached subcontract report for additional analysis and fertilizer recommendations

Leander Hills WWTP Soil 0-6 Inches		Collected: 09/22/23 10:10 by Mark Asher and Bryce Jones Received: 09/22/23 13:40 by Bryce Jones					Type Comp	Matrix Solid	C-O-C #			
Lab ID#	G031747-01	Result	Units	Notes	MDL	Adj MDL	SQL	Lab	Analyzed	Method	Batch	
General Chemistry												
% Solids		86.4	g/100g (%)		0.10	0.10	0.10	Austin	09/26/23 12:46 ATG	SM2540 G 2015	M167189	NEL
Total Kjeldahl Nitrogen as N		1290	mg/kg dry		0.13	37.5	57.6	Bryan	10/03/23 14:50 KMA	SM4500-NH3 G 2011	M167523	ANR
Plant Available Parameters												
Total Nitrogen		1330	mg/kg dry wt.		N/A	N/A	Calc		10/18/23 11:59 PMY	Calculation	M168237	ANR
Please see the attached subcontract report for subcontracted data.												

Leander Hills WWTP Soil 6-18 Inches		Collected: 09/22/23 10:10 by Mark Asher and Bryce Jones Received: 09/22/23 13:40 by Bryce Jones					Type Comp	Matrix Solid	C-O-C #			
Lab ID#	G031747-02	Result	Units	Notes	MDL	Adj MDL	SQL	Lab	Analyzed	Method	Batch	
General Chemistry												
% Solids		85.5	g/100g (%)		0.10	0.10	0.10	Austin	09/26/23 12:46 ATG	SM2540 G 2015	M167190	NEL
Total Kjeldahl Nitrogen as N		958	mg/kg dry		0.13	38.0	58.4	Bryan	10/03/23 14:50 KMA	SM4500-NH3 G 2011	M167523	ANR
Plant Available Parameters												
Total Nitrogen		993	mg/kg dry wt.		N/A	N/A	Calc		10/18/23 11:59 PMY	Calculation	M168237	ANR
Please see the attached subcontract report for subcontracted data.												

Leander Hills WWTP Soil 18-30 Inches		Collected: 09/22/23 10:10 by Mark Asher and Bryce Jones Received: 09/22/23 13:40 by Bryce Jones					Type Comp	Matrix Solid	C-O-C #			
Lab ID#	G031747-03	Result	Units	Notes	MDL	Adj MDL	SQL	Lab	Analyzed	Method	Batch	
General Chemistry												
% Solids		81.6	g/100g (%)		0.10	0.10	0.10	Austin	09/26/23 12:46 ATG	SM2540 G 2015	M167190	NEL
Total Kjeldahl Nitrogen as N		1350	mg/kg dry		0.13	39.6	61.0	Bryan	10/03/23 14:50 KMA	SM4500-NH3 G 2011	M167523	ANR
Plant Available Parameters												
Total Nitrogen		1390	mg/kg dry wt.		N/A	N/A	Calc		10/18/23 11:59 PMY	Calculation	M168237	ANR
Please see the attached subcontract report for subcontracted data.												

BRYAN FACILITY
 635 Phil Gramm Boulevard
 Bryan, TX 77807
 Phone: (979) 778-3707
 Fax: (979) 778-3193



AUSTIN FACILITY
 3512 Montopolis Dr. Suite A
 Austin, TX 78744
 Phone: (512) 301-9559
 Fax: (512) 301-9552

Analytical Report

Aqua-Texas, Inc.
 Report Printed: 10/18/23 12:48
 G031747

General Chemistry - Quality Control

Result	Units	Notes	MDL	SQL	Analyzed	Spike Amount	Source Result	%R	%R Limits	RPD	RPD Limit	Batch
% Solids - SM2540 G 2015												
Blank	<0.10	g/100g (%)	0.10	0.10	09/26/23 12:46 ATG							M167189
Duplicate	3.74	%	0.100	0.100	09/26/23 12:46 MAM		3.73			0.268	5.81	M167189
Duplicate	3.74	g/100g (%)	0.10	0.10	09/26/23 12:46 ATG		3.73			0.268	10	M167189
Blank	<0.10	g/100g (%)	0.10	0.10	09/26/23 12:46 ATG							M167190
Duplicate	85.5	%	0.100	0.100	09/26/23 12:46 MAM		85.5			0.00	5.81	M167190
Duplicate	85.5	g/100g (%)	0.10	0.10	09/26/23 12:46 ATG		85.5			0.00	10	M167190
Total Kjeldahl Nitrogen as N - SM4500-NH3 G 2011												
Initial Cal Check	9.07	mg/L			10/03/23 14:50 KMA	9.12		99.4	90 - 110			2310014
Low Cal Check	0.22	mg/L			10/03/23 14:50 KMA	0.200		109	70 - 130			2310014
Blank	<0.20	mg/kg wet	0.13	0.20	10/03/23 14:50 KMA							M167523
LCS	8.10	mg/kg wet	0.13	0.20	10/03/23 14:50 KMA	8.00		101	85 - 115			M167523
LCS Dup	8.18	mg/kg wet	0.13	0.20	10/03/23 14:50 KMA	8.00		102	85 - 115	0.909	10	M167523
Matrix Spike	5860	mg/kg dry	144	221	10/03/23 14:50 KMA	4420	1090	108	70 - 130			M167523
Matrix Spike Dup	6040	mg/kg dry	144	221	10/03/23 14:50 KMA	4420	1090	112	70 - 130	3.73	20	M167523
Reference	995	mg/kg wet	32.3	49.7	10/03/23 14:50 KMA	1080		92.1	90 - 110			M167523


Sample Preparation Summary

Sample	Method	Prepared	Lab	Bottle	Initial	Units	Final	Units	External Dilution Factor	Batch
G031747-01										
% Solids	SM2540 G 2015	9/26/23 12:46 MAM	Austin	C	10.0	g	10.0	mL	1	M167189
Subcontract	Sub Contract Data Entry	10/17/23 8:55 PMY	Bryan	-	-	-	-	-	-	M168164
Total Kjeldahl Nitrogen as N	SM4500-NH3 G 2011	10/3/23 9:19 KMA	Bryan	B	0.100	g	25.0	mL	1	M167523
Total Nitrogen	Calculation	10/18/23 11:59 PMY			1.00	g	1.00	mL	1	M168237
G031747-02										
% Solids	SM2540 G 2015	9/26/23 12:46 MAM	Austin	C	10.0	g	10.0	mL	1	M167190
Subcontract	Sub Contract Data Entry	10/17/23 8:55 PMY	Bryan	-	-	-	-	-	-	M168164
Total Kjeldahl Nitrogen as N	SM4500-NH3 G 2011	10/3/23 9:19 KMA	Bryan	B	0.100	g	25.0	mL	1	M167523
Total Nitrogen	Calculation	10/18/23 11:59 PMY			1.00	g	1.00	mL	1	M168237
G031747-03										
% Solids	SM2540 G 2015	9/26/23 12:46 MAM	Austin	C	10.0	g	10.0	mL	1	M167190
Subcontract	Sub Contract Data Entry	10/17/23 8:55 PMY	Bryan	-	-	-	-	-	-	M168164
Total Kjeldahl Nitrogen as N	SM4500-NH3 G 2011	10/3/23 9:19 KMA	Bryan	B	0.100	g	25.0	mL	1	M167523
Total Nitrogen	Calculation	10/18/23 11:59 PMY			1.00	g	1.00	mL	1	M168237

G031747

Leander Hills WWTP Soil Sampling Map

X = Locations samples were collected



Report generated for:
Aqua-Tech Laboratories, Inc.
635 Phil Gramm Blvd
BRYAN, TX 77807

Soil Analysis Report

Soil, Water and Forage Testing Laboratory
Department of Soil and Crop Sciences
2478 TAMU
College Station, TX 77843-2478
979-845-4816 (phone)
979-845-5958 (FAX)
Visit our website: <http://soiltesting.tamu.edu>

Sample received on: 9/27/2023
Printed on: 10/9/2023
Area Represented: 1.09 acres

Brazos County
Laboratory Number: 640994
Customer Sample ID: G031747-01

Crop Grown: **BLUESTEM (GRAZING OR HAY)**

Analysis	Results	CL*	Units	ExLow	VLow	Low	Mod	High	VHigh	Excess.	Fertilizer Recommended	
pH	8.1	(5.8)	-	Mod. Alkaline								
Conductivity	134	(-)	umho/cm	None							CL*	Fertilizer Recommended
Nitrate-N	40	(-)	ppm**	[Bar chart showing distribution]								0 lbs N/acre
Phosphorus	22	(50)	ppm	[Bar chart showing distribution]								30 lbs P2O5/acre
Potassium	395	(125)	ppm	[Bar chart showing distribution]								0 lbs K2O/acre
Calcium	20,254	(180)	ppm	[Bar chart showing distribution]								0 lbs Ca/acre
Magnesium	446	(50)	ppm	[Bar chart showing distribution]								0 lbs Mg/acre
Sulfur	131	(13)	ppm	[Bar chart showing distribution]								0 lbs S/acre
Sodium	29	(-)	ppm	[Bar chart showing distribution]								
Iron				[Bar chart showing distribution]								
Zinc				[Bar chart showing distribution]								
Manganese				[Bar chart showing distribution]								
Copper				[Bar chart showing distribution]								
Boron				[Bar chart showing distribution]								
Limestone Requirement												0.00 tons 100ECCE/acre
Total N	2234		ppm									

*CL=Critical level is the point which no additional nutrient (excluding nitrate-N, sodium and conductivity) is recommended. **ppm=mg/kg

Nitrogen: Apply an additional 30 lbs/A of nitrogen prior to each four to six week graze down..

New online fertilizer calculators have been placed on the laboratory's website to determine appropriate fertilizers to purchase and determine their application rates.
<http://soiltesting.tamu.edu/webpages/calculator.html>

Methods: pH and conductivity/ 2:1; nitrate-N/Cd-red.; P, K, Ca, Mg, Na, and S/Mehlich 3 by ICP; Fe, Zn, Mn, and Cu/DTPA by ICP; and B/hot water by ICP.

ProAnalysis/Ver. 2.19j

Report generated for:
Aqua-Tech Laboratories, Inc.
635 Phil Gramm Blvd
BRYAN, TX 77807

Soil Analysis Report

Soil, Water and Forage Testing Laboratory
Department of Soil and Crop Sciences
2478 TAMU
College Station, TX 77843-2478
979-845-4816 (phone)
979-845-5958 (FAX)
Visit our website: <http://soiltesting.tamu.edu>

Sample received on: 9/27/2023
Printed on: 10/9/2023
Area Represented: 1.09 acres

Brazos County
Laboratory Number: 640995
Customer Sample ID: G031747-02

Crop Grown: **BLUESTEM (GRAZING OR HAY)**

Analysis	Results	CL*	Units	ExLow	VLow	Low	Mod	High	VHigh	Excess.	Fertilizer Recommended
pH	8.2	(5.8)	-	Mod. Alkaline							
Conductivity	156	(-)	umho/cm	None							
Nitrate-N	35	(-)	ppm**	CL*							0 lbs N/acre
Phosphorus	15	(50)	ppm	[Bar chart showing level between VLow and Low]							35 lbs P2O5/acre
Potassium	330	(125)	ppm	[Bar chart showing level between Low and High]							0 lbs K2O/acre
Calcium	19,236	(180)	ppm	[Bar chart showing level between High and VHigh]							0 lbs Ca/acre
Magnesium	444	(50)	ppm	[Bar chart showing level between High and VHigh]							0 lbs Mg/acre
Sulfur	127	(13)	ppm	[Bar chart showing level between High and VHigh]							0 lbs S/acre
Sodium	44	(-)	ppm	[Bar chart showing level between ExLow and VLow]							
Iron				[Bar chart showing level between ExLow and VLow]							
Zinc				[Bar chart showing level between ExLow and VLow]							
Manganese				[Bar chart showing level between ExLow and VLow]							
Copper				[Bar chart showing level between ExLow and VLow]							
Boron				[Bar chart showing level between ExLow and VLow]							
Limestone Requirement											0.00 tons 100ECCE/acre
Total N	2098		ppm								

*CL=Critical level is the point which no additional nutrient (excluding nitrate-N, sodium and conductivity) is recommended. **ppm=mg/kg

Nitrogen: Apply an additional 30 lbs/A of nitrogen prior to each four to six week graze down..

New online fertilizer calculators have been placed on the laboratory's website to determine appropriate fertilizers to purchase and determine their application rates.
<http://soiltesting.tamu.edu/webpages/calculator.html>

Methods: pH and conductivity/ 2:1; nitrate-N/Cd-red.; P, K, Ca, Mg, Na, and S/Mehlich 3 by ICP; Fe, Zn, Mn, and Cu/DTPA by ICP; and B/hot water by ICP.

ProAnalysis/Ver. 2.19j

Report generated for:
Aqua-Tech Laboratories, Inc.
635 Phil Gramm Blvd
BRYAN, TX 77807

Soil Analysis Report

Soil, Water and Forage Testing Laboratory
Department of Soil and Crop Sciences
2478 TAMU
College Station, TX 77843-2478
979-845-4816 (phone)
979-845-5958 (FAX)
Visit our website: <http://soiltesting.tamu.edu>

Sample received on: 9/27/2023
Printed on: 10/9/2023
Area Represented: 1.09 acres

Brazos County
Laboratory Number: 640996
Customer Sample ID: G031747-03
Crop Grown: **BLUESTEM (GRAZING OR HAY)**

Analysis	Results	CL*	Units	ExLow	VLow	Low	Mod	High	VHigh	Excess.		
pH	8.2	(5.8)	-	Mod. Alkaline								
Conductivity	297	(-)	umho/cm	None							CL*	Fertilizer Recommended
Nitrate-N	41	(-)	ppm**	[Bar chart showing levels across ExLow to VHigh]								0 lbs N/acre
Phosphorus	19	(50)	ppm	[Bar chart showing levels across ExLow to VHigh]								30 lbs P2O5/acre
Potassium	369	(125)	ppm	[Bar chart showing levels across ExLow to VHigh]								0 lbs K2O/acre
Calcium	18,902	(180)	ppm	[Bar chart showing levels across ExLow to VHigh]								0 lbs Ca/acre
Magnesium	438	(50)	ppm	[Bar chart showing levels across ExLow to VHigh]								0 lbs Mg/acre
Sulfur	124	(13)	ppm	[Bar chart showing levels across ExLow to VHigh]								0 lbs S/acre
Sodium	41	(-)	ppm	[Bar chart showing levels across ExLow to VHigh]								
Iron				[Bar chart showing levels across ExLow to VHigh]								
Zinc				[Bar chart showing levels across ExLow to VHigh]								
Manganese				[Bar chart showing levels across ExLow to VHigh]								
Copper				[Bar chart showing levels across ExLow to VHigh]								
Boron				[Bar chart showing levels across ExLow to VHigh]								
Limestone Requirement												0.00 tons 100ECCE/acre
Total N	2474		ppm									

*CL=Critical level is the point which no additional nutrient (excluding nitrate-N, sodium and conductivity) is recommended. **ppm=mg/kg

Nitrogen: Apply an additional 30 lbs/A of nitrogen prior to each four to six week graze down..

New online fertilizer calculators have been placed on the laboratory's website to determine appropriate fertilizers to purchase and determine their application rates.
<http://soiltesting.tamu.edu/webpages/calculator.html>

Methods: pH and conductivity/ 2:1; nitrate-N/Cd-red.; P, K, Ca, Mg, Na, and S/Mehlich 3 by ICP; Fe, Zn, Mn, and Cu/DTPA by ICP; and B/hot water by ICP.

ProAnalysisVer. 2.19j



Chain-of-Custody and Analysis Request

All analyses must be performed by a TNI approved method certified by the TCEQ. Contact ATL's sample custodian via voice and email if your methods do not meet this criteria.



Aqua-Tech laboratories, Inc.

Austin Bryan
 3512 Montopolis Dr. Suite A 635 Phil Gramm Blvd
 Austin, TX 78744 Bryan, TX 77807
 512.301.9559 979.776.3707

C-O-C # 955 - G031747

Page 1 of 2

SHIPPED TO
TAMU - Soil Lab
 2610 F&B Road
 College Station, TX 77845
 Phone: (979) 845-4816

DEFINITIONS	P	Plastic
	G	Glass
	L	Liter
	CM	Custody Maintained
	CTU	Custody Transfer Unbroken
	ATL	Aqua-Tech Laboratories, Inc

Comments:

Please use Sample ID as PO# and email reports to reporting@aquatechlabs.com.

Lines below document condition at receipt in lab (shipped to) listed above.

Cooler ID	Temp Read (C)	Corrected Temp (C)	Thermometer ID	Please hold coolers for pick-up.

Sample Custody			
Relinquished (print & sign)	<input checked="" type="checkbox"/> Sampler <input type="checkbox"/> Client <input checked="" type="checkbox"/> ATL Field	Date: 9-27-23 Time: 1009	<input checked="" type="checkbox"/> Iced / Refrig <input type="checkbox"/> Custody Sealed
Received (print & sign)	<input type="checkbox"/> Client <input type="checkbox"/> ATL Field	Date: _____ Time: _____	<input type="checkbox"/> Iced / Refrig <input type="checkbox"/> CM / CTU
Relinquished (print & sign)	<input type="checkbox"/> Client <input type="checkbox"/> ATL Field	Date: _____ Time: _____	<input type="checkbox"/> Iced / Refrig <input type="checkbox"/> CM / CTU
Received (print & sign)	<input type="checkbox"/> Client <input type="checkbox"/> ATL Field	Date: _____ Time: _____	<input type="checkbox"/> Iced / Refrig <input type="checkbox"/> CM / CTU
Relinquished (print & sign)	<input type="checkbox"/> Client <input checked="" type="checkbox"/> ATL Field	Date: 9-27-23 Time: 1028	<input checked="" type="checkbox"/> Iced / Refrig <input checked="" type="checkbox"/> CM / CTU / Sealed
Received (print & sign)	<input checked="" type="checkbox"/> Lab	Date: 9/27/23 Time: 1028	<input checked="" type="checkbox"/> Cond Good <input checked="" type="checkbox"/> Iced / Refrig <input type="checkbox"/> CM / CTU

Sample ID Sampled / Matrix	Analysis Request	(ATL indicates cooler number in parentheses for each container - only required if more than one cooler listed above.)	Lab ID
G031747-01 09/22/23 10:10 Soil	<p><i>Calculation</i></p> <p>Total N Calc</p> <p><i>Mehlich 3 - TAMU</i></p> <p>P Plant Available NO3N Extractable K Plant Available</p> <p><i>TAMU - 1:2 Soil Extract</i></p> <p>pH Conductivity (1:2)</p>		
G031747-02 09/22/23 10:10 Soil	<p><i>Calculation</i></p> <p>Total N Calc</p> <p><i>Mehlich 3 - TAMU</i></p> <p>P Plant Available NO3N Extractable K Plant Available</p> <p><i>TAMU - 1:2 Soil Extract</i></p> <p>pH Conductivity (1:2)</p>		



Chain-of-Custody and Analysis Request

C-O-C #
955 - G031747

SHIPPED TO: TAMU - Soil Lab

Page 2 of 2

Sample ID Sampled / Matrix	Analysis Request	(ATL indicates cooler number in parentheses for each container - only required if more than one cooler listed above.)	Lab ID
G031747-03 09/22/23 10:10 Soil	<i>Calculation</i>		
	Total N Calc		
	<i>Mehlich 3 - TAMU</i>		
	P Plant Available NO3N Extractable K Plant Available		
	<i>TAMU - 1:2 Soil Extract</i>		
pH	Conductivity (1:2)		

Attachment F

Sludge Hauling Letter

City Of Manor

201 East Parsons Street
Manor, TX 78653
(512) 272-5555

Contact Info: Phillip McCammon – Sheridan Environmental
512-699-4326

Plant info: Wilbarger WWTP - TPDES Permit No. WQ0012900001 – EPA No. TX0095184
Address: 547 Llano Street, Manor, Texas. 78653

Dear Sir,

City Of Manor Wilbarger Creek WWTP operates/owns a disposal site that will accept Wastewater Treatment Plant Sludge (class B). All sludge must meet all parameters for (class B) sludge and will need analytical testing ("TCLP"). Sludge will only be accepted when hauled by a pre-approved transportation company authorized for disposal to the listed site.

Site: – Wilbarger WWTP - WQ0012900001 – Is accepting Wastewater Sludge at this site and is expected to be open for the next five years. Acceptance for disposal of Wastewater Sludge for Leander Hills WWTP - WQ0013337-001 is granted provided all parameters above are adhered. The City Of Manor reserves the right to discontinue disposal from this site if at any time the sludge is found to cause problems to the treatment system, and for any other reason that the City Of Manor would deem necessary.

Authorizing Signature: _____

Print _____

Phillip McCammon II

Date 05 / 28 / 2014

Re: [EXTERNAL] Re: Application to Renew Permit No. WQ0013337001 - Notice of Deficiency Letter

Stephanie Landsman <stephanie@landsmanenviro.com>

Mon 7/15/2024 2:03 PM

To:Savannah Jackson <Savannah.Jackson@tceq.texas.gov>

Cc:Bautista, Abel M <AMBautista@aguaamerica.com>

We will do everything we can to respond in a timely manner but there needs to be more understanding in this case-everyone in southeast Texas is suffering at the moment.

On Mon, Jul 15, 2024 at 2:00PM Savannah Jackson <Savannah.Jackson@tceq.texas.gov> wrote:

Good Afternoon,

I am sorry to hear that. Unfortunately, we still have to follow the same protocol as usual if we don't receive a response by the due date. We will be sending out a 2nd NOD that gives 30 days for a response, so you should have plenty of time to provide a complete response, as that is even longer than the 2-week extension you are asking for. I wish y'all the best getting your facilities up and running!

Thanks,



Savannah Jackson
Texas Commission on Environmental Quality
Water Quality Division
512-239-4306
savannah.jackson@tceq.texas.gov

From: Bautista, Abel M <AMBautista@aguaamerica.com>
Sent: Monday, July 15, 2024 1:23 PM
To: Savannah Jackson <Savannah.Jackson@tceq.texas.gov>; Stephanie Landsman <stephanie@landsmanenviro.com>
Subject: RE: [EXTERNAL] Re: Application to Renew Permit No. WQ0013337001 - Notice of Deficiency Letter

Ms. Jackson,

I am not sure if you are aware that several areas within the Houston area are still with no power due to Hurricane Beryl. So we have been very busy getting the facilities up and running and the renewal of the permits are currently not our priority. Therefore, we are asking for a two week extension in order to respond to the requests.

Regards,

Abel Bautista
281.651.0174 ext. 54119

From: Savannah Jackson <Savannah.Jackson@tceq.texas.gov>
Sent: Monday, July 15, 2024 11:41 AM
To: Stephanie Landsman <stephanie@landsmanenviro.com>; Bautista, Abel M <AMBautista@aguaamerica.com>
Subject: [EXTERNAL] Re: Application to Renew Permit No. WQ0013337001 - Notice of Deficiency Letter

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good Morning,

Just a reminder that the complete response for this application is due today!

Thanks,



Savannah Jackson
Texas Commission on Environmental Quality
Water Quality Division
512-239-4306
savannah.jackson@tceq.texas.gov

From: Savannah Jackson <Savannah.Jackson@tceq.texas.gov>
Sent: Tuesday, July 2, 2024 9:37 AM
To: Stephanie Landsman <stephanie@landsmanenviro.com>; Bautista, Abel M <AMBautista@aguaamerica.com>
Subject: Re: Application to Renew Permit No. WQ0013337001 - Notice of Deficiency Letter

Good Morning,

Great, thank you. Yes you can go ahead and add it!

Thanks,



Savannah Jackson
Texas Commission on Environmental Quality
Water Quality Division
512-239-4306
savannah.jackson@tceq.texas.gov

From: Stephanie Landsman <stephanie@landsmenenviro.com>
Sent: Monday, July 1, 2024 3:23 PM
To: Savannah Jackson <Savannah.Jackson@tceq.texas.gov>; Bautista, Abel M <AMBautista@aguaamerica.com>
Subject: Re: Application to Renew Permit No. WQ0013337001 - Notice of Deficiency Letter

Here is the revised public viewing location. Can I just insert that into the NORI before I get it translated?

On Mon, Jul 1, 2024 at 1:34 PM Savannah Jackson <Savannah.Jackson@tceq.texas.gov> wrote:

Dear Ms. Stephanie Landsman,

The attached Notice of Deficiency letter sent on July 1, 2024, requests additional information needed to declare the application administratively complete. Please send the complete response to my attention by July 15, 2024.

Thank you,



Savannah Jackson
Texas Commission on Environmental Quality
Water Quality Division
512-239-4306
savannah.jackson@tceq.texas.gov

Stephanie Landsman
Wastewater Specialist
Landsman Environmental LLC
9597 Jones Road #962
Jersey Village, TX 77065
(281)-658-5899



Stephanie Landsman
Wastewater Specialist
Landsman Environmental LLC
9597 Jones Road #962
Jersey Village, TX 77065
(281)-658-5899



Re: Public Viewing Location Error - Application for Permit No. WQ000013337001-Notice of Deficiency 30-Day Will Return Letter

Stephanie Landsman <stephanie@landsmanenviro.com>

Fri 7/19/2024 4:04 AM

To:Savannah Jackson <Savannah.Jackson@tceq.texas.gov>;Bautista, Abel M <AMBautista@aquamerica.com>

2 attachments (1 MB)

Aqua Texas Spanish wq tlap (2).docx; Leander Public Viewing.pdf;

On Thu, Jul 18, 2024 at 2:40PM Savannah Jackson <Savannah.Jackson@tceq.texas.gov> wrote:

Good Afternoon,

Upon review, I noticed that this public viewing location is actually located in Williamson County, but the public viewing location must match the facility county, which is Travis County. Please provide a public viewing location in Travis County instead. Let me know if you have any questions.

Thanks,



Savannah Jackson
Texas Commission on Environmental Quality
Water Quality Division
512-239-4306
savannah.jackson@tceq.texas.gov

From: Rachel Ellis <Rachel.Ellis@tceq.texas.gov>
Sent: Thursday, July 18, 2024 11:36 AM
To: Savannah Jackson <Savannah.Jackson@tceq.texas.gov>
Subject: FW: Application for Permit No. WQ000013337001-Notice of Deficiency 30-Day Will Return Letter

Texas Commission on Environmental Quality
Water Quality Division
Application Review & Processing Team
Rachel.Ellis@tceq.texas.gov



From: Stephanie Landsman <stephanie@landsmanenviro.com>
Sent: Thursday, July 18, 2024 10:23 AM
To: Rachel Ellis <Rachel.Ellis@tceq.texas.gov>; Bautista, Abel M <AMBautista@aquamerica.com>
Subject: Re: Application for Permit No. WQ000013337001-Notice of Deficiency 30-Day Will Return Letter

Attached is the revised application page and the translated NORI for this application.

On Thu, Jul 18, 2024 at 10:04 AM Rachel Ellis <Rachel.Ellis@tceq.texas.gov> wrote:

Dear applicant,

The attached Notice of Deficiency 30-Day Will Return Letter was mailed on **July 18, 2024**, requesting additional information needed to declare the application administratively complete. Please mail an original and two copies (with a cover letter) of the complete response by **August 17, 2024**.

Regards,

Texas Commission on Environmental Quality
Water Quality Division
Application Review & Processing Team
Rachel.Ellis@tceq.texas.gov



--
Stephanie Landsman
Wastewater Specialist
Landsman Environmental LLC
9597 Jones Road #962
Jersey Village, TX 77065
(281)-658-5899



--
Stephanie Landsman
Wastewater Specialist
Landsman Environmental LLC
9597 Jones Road #962
Jersey Village, TX 77065
(281)-658-5899



Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: Wastewater Compliance Coordinator

Organization Name: Aqua Texas, Inc.

Phone No.: 281-651-0174 Ext.: 54119

E-mail: abautista@aquaaamerica.com

D. Public Viewing Information

If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.

Public building name: Austin Public Library -Milwood Branch

Location within the building: [REDACTED]

Physical Address of Building: 12500 Amherst Dr.

City: Austin

County: Travis

Contact Name: [REDACTED]

Phone No.: 512-974-9880 Ext.: [REDACTED]

E. Bilingual Notice Requirements:

This information **is required** for **new, major amendment, minor amendment or minor modification, and renewal applications.**

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

Yes No

If **no**, publication of an alternative language notice is not required; **skip to** Section 9 below.

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

Yes No

3. Do the students at these schools attend a bilingual education program at another location?

Yes No

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0013337001

SOLICITUD. Aqua Texas, Inc., 1106 Clayton Lane, Suite 400W, Austin, Texas 78723, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso para la Aplicación en Terrenos de Texas (TLAP) No. WQ0013337001 para autorizar la disposición de efluente de aguas residuales tratadas en un flujo promedio diario que no exceda 15,000 galones mediante la absorción y eliminación del suelo subterráneo con un área mínima de 45,000 pies cuadrados de acceso no público. La instalación de tratamiento de aguas residuales domésticas y el sitio de disposición están ubicados aproximadamente 6.5 millas al noroeste de la intersección de Farm-to-Market Road 1431 y Farm-to-Market Road 2243, en el Condado de Travis, Texas 78641. La TCEQ recibió esta solicitud el 27 de junio de 2024. La solicitud del permiso está disponible para leerla y copiarla en la Biblioteca Pública de Austin - Sucursal Milwood, 12500 Aherst Dr., Austin, TX 78727, antes de la fecha de publicación de este aviso en el periódico. La solicitud, incluidas las actualizaciones y los avisos asociados, están disponibles electrónicamente en la siguiente página web:

<https://www.tceq.texas.gov/permitting/wastewater/pendingpermits/tlap-applications>. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=97.989166,30.584166&level=18>

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas

designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía <http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional de Aqua Texas, Inc. a la dirección indicada arriba o llamando al Sr. Abel Bautista, Coordinador de Cumplimiento de Aguas Residuales, al 281-651-0174.

Fecha de emisión: