

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Aqua Texas, Inc. (CN604062463) operates Brushy Creek Wastewater Treatment Facility RN101203685. a domestic wastewater treatment facility. The facility is located at 23919 Brushy Woods, in Hockley, Montgomery County, Texas 77447.

Request for renewal of permit to discharge 75,000 gallons of treated domestic wastewater daily.

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen and E coli.. Domestic Wastewater discharged is treated by *activated sludge in the complete mix mode. Sewage is pumped from the lift station through a coarse bar screen to the aeration basin. The mixed liquor flows to the clarifier where solids settle to the bottom of the basin and clear water flows over the weirs. The water then flows into the chlorine contact chamber and treated effluent flows to the receiving stream. The settled solids in the bottom of the clarifier are either pumped to the digester or to the aeration basin..*

