

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

## **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Aqua Texas, Inc.) (CN604062463 ) operates Merenco Wastewater Treatment Facility RN107596207. a domestic wastewater treatment facility. The facility is located approximately 4,200 feet west of Humble Road and State Highway 249, in Tomball, Harris County, Texas 77375.

Renewal to discharge 62,500 gallons of treated domestic wastewater per day. *<<For TLAP applications include the following sentence, otherwise delete:>>*

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen and E. coli.. Domestic Wastewater discharges only. is treated by The facility will employ the complete mix variation of the activated sludge process designed for single stage nitrification. From the lift station the wastewater will travel through a coarse bar screen then to the complete mix basin; from the basin the mixed liquor will be transferred to the clarifier where solids will be settled out and clear water will flow over the weirs then into the chlorine contact basin. The settled solids will either be transferred to the digester or returned to the headworks..

