

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Brazoria County M.U.D. No. 25 (CN 600736003) proposes to operate Brazoria County M.U.D. No. 25 Wastewater Treatment Plant, RN 102896248. a facility to discharge treated wastewater. The facility is located at 3451 1/2 Southfork Freeway, in Manvel, Brazoria County, Texas 77578.

This application is for the renewal to discharge at an annual average flow of 480,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and Escherichia coli. The domestic wastewater is treated by *screening, aeration, digestion, secondary clarification, and chlorination.*

