

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Christian Tabernacle of Houston, Inc. (CN600862189) operates the Christian Tabernacle Wastewater Treatment Facility RN101611473. a domestic wastewater treatment facility. The facility is located North side of Garrett Road, approximately 0.262 miles west of the intersection of Beltway 8 and Garrett Road., in Houston, Harris County, Texas 77049.

Renewal request to discharge 19,000 gallons of treated domestic wastewater per day.

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen, Total Kjeldahl Nitrogen and E. coli. Treated domestic wastewater. is treated by *by lift station through force main into aeration basin via bar screen; then to clarifier, then through chlorine contact basin, then to the outfall. Sludge is wasted into the digester where it is concentrated and then wet hauled by a contractor..*

