

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Alice (CN600740666) operates Southside Wastewater Treatment Facility RN101609105. a domestic wastewater treatment facility. The facility is located 286 County Road 383, in Alice, Jim Wells County, Texas 78332.

This application is for a renewal to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 2,600,000 gallons per day.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), and ammonia nitrogen (NH₃-N). Additional pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent of the permit application package. Municipal wastewater is treated by the conventional treatment process and the treatment units include aerobic digesters, aeration basins, sludge drying beds, clarifiers, and chlorine contact chambers.