

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Angleton (CN600638670) operates Oyster Creek Wastewater Treatment Plant RN102179785. a Wastewater Treatment Plant. The facility is located 500 Sebesta Road, in Angleton, Brazoria County, Texas 77515.

Request is for the renewal of the TCEQ TPDES permit WQ0010548004

Discharges from the facility are expected to contain low concentrations of pollutants typical after treatment of domestic wastewater such as carbonaceous biochemical oxygen demand, total suspended solids, ammonia nitrogen, total Kjeldahl nitrogen, and E. coli. Domestic Wastewater is treated by a *conventional waste activated sludge process where the flow enters the wastewater treatment plant from an on-site lift station, followed by a bar screen, then aeration basins, clarifiers, chlorine contact chamber, for disinfection, dichlorination, and discharge. Sludge from the bottom of the clarifier is either returned to the aeration basin or wasted to the digester. Digested sludge is partially dewatered by belt press then hauled away.*

