

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

The City of Beaumont (CN600130439) operates Hillebrandt Wastewater Treatment Facility (RN101612224), an activated sludge process plant with constructed wetlands. The facility is located at 4900 Lafin Drive, in Beaumont, Jefferson County, Texas 77705.

This application is for a renewal to discharge at an annual average flow of 31,900,000 gallons per day (GPD) of treated domestic wastewater via Outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Additional potential parameters are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by rock trap basins, two bar screens, four primary clarifiers, two primary trickling filters, two secondary trickling filters, four final clarifiers, aerated lagoons, two chlorine contact basins, a dechlorination ditch, constructed wetlands, eight cyclone degritters, two aerobic digesters, three belt presses, two sludge thickeners, twenty-eight drying beds, and a flow equalization basin.