

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Cedar Park (CN600407951) operates the City of Cedar Park Water Reclamation Facility (RN102845914). a water treatment facility. The facility is located at 2315 Brushy Creek Loop, in Cedar Park, Williamson County, Texas 78613.

City of Cedar Park, 450 Cypress Creek Road, Cedar Park, Texas 78613, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0012308001 (EPA I.D. No. TX0085740) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 5,000,000 gallons per day. The domestic wastewater treatment facility is located at 2315 Brushy Creek Loop, Cedar Park, in Williamson County, Texas 78613. The discharge route is from the plant site via a pipeline to South Brushy Creek; thence to Cedar Park Lake; thence to South Brushy Creek; thence to Brushy Creek. TCEQ received this application on March 1, 2023. The permit application is available for viewing and copying at the City of Cedar Park Public Works Building 1, 2401 Brushy Creek Loop, Cedar Park, Texas. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For exact location, refer to application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.80636,30.495054&level=18>

Discharges from the facility are expected to contain suspended solids, ammonia nitrogen, and phosphorus. The discharge from this facility is primarily domestic wastewater discharge that is treated by activated sludge, anoxic/anaerobic basins, aeration basins, clarifiers, tertiary filters, chlorination, and dechlorination.

