

**Plain Language Summary for Texas Pollutant Discharge Elimination System
(TPDES)**

For

City of Crawford

PO Box 7

Crawford, TX 76634

WQ0010656001 – EPA TX0054666

The City of Crawford Water Quality Permit No. WQ0010656001 (EPA ID No. TX0054666), CN600735559 operates the City of Crawford's wastewater treatment plant RN101916484.

Domestic wastewater is treated by a 3 pond system.

Pond #1 is a facultative lagoon, Pond #2 is a stabilization pond, and Pond #3 is a stabilization pond.

The treatment facility is located at 250 South Avenue N, Crawford Texas, in McLennan County, Texas 76638.

This application is for a renewal to discharge at an annual average flow rate not to exceed 90,000 gallons per day of treated domestic wastewater via Outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package.

RECEIVED

OCT 09 2023

Water Quality Applications Team