

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Cushing (CN600683072) operates City of Cushing Wastewater Treatment Plant RN101917151. an activated sludge extended aeration plant. The facility is located approximately 200 feet south of the intersection of Fourth Street and Spruce Avenue, in Cushing, Nacogdoches County, Texas 75760.

This application is for a renewal to discharge at a daily average flow of 80,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain Biochemical Oxygen Demand (5-day), Total Suspended Solids, Escherichia coli. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by *an activated sludge extended aeration plant and the treatment units include a bar screen and grit channel, an Imhoff Tank, two (2) aerobic stabilization ponds, and a chlorine contact chamber.*

