

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Eastland (CN600338222) operates Eastland Wastewater Treatment Plant, RN101919314,, a domestic wastewater treatment plant. The facility is located at the east end of Smith Street, approximately one mile southeast of the intersection of State Highway 6 and State highway 12, and 1.4 miles northeast of the intersection of State Highway 6 and Interstate Highway 20, in Eastland, Eastland County, Texas 76448.

The City of Eastland has applied for a renewal of the existing permit that authorizes the discharge of treated domestic effluent at a daily average flow not to exceed 0.90 million gallons per day.

Discharges from the facility are expected to contain Carbonaceous Biological Oxygen Demand 5-day, Total Suspended Solids, Ammonia Nitrogen, and E. Coli. Domestic wastewater is treated by wastewater is treated by an activated sludge plant operated in the sequencing batch reactor (SBR) mode.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS