

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City Of Groesbeck (CN600241400) operates City of Groesbeck Wastewater Treatment Plant RN101918944. a extended aeration followed by clarification. The facility is located 803 N Tyus St, in Groesbeck, Limestone County, Texas 76642.

This application is for renewal to discharge a volume not to exceed a daily average flow of 0.709 million gallons per day of treated wastewater via outfall.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅) total suspended solids (TSS), ammonia nitrogen (NH₃-N) and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater is treated by Extended aeration followed by clarification. Influent flows into headworks, through rapid mix chamber, into aeration basin, then to clarifier. Sludge goes to aerobic digester, then to sludge dewatering boxes, and then hauled off to landfill.