

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

City of Hamilton (600626279 ) operates a domestic wastewater treatment plant (RN101918068). an activated sludge wastewater plant operated in the extended aeration mode. The facility is located 700 N. Lloyd Street, in Hamilton, Hamilton County, Texas 76531.

City of Hamilton has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of the Texas Pollutant Discharge Elimination System (TPDES) which authorizes the discharge of treated domestic wastewater at an annual average flow not to exceed 620,000 gallons per day.

Discharges from the facility are expected to contain CBOD<sub>5</sub>, Total Suspended Solids, Ammonia Nitrogen, Nitrate Nitrogen, Sulfate, Chloride, Phosphorus, Dissolved Oxygen, E.coli, Total Dissolved Solids, oil and grease, Aluminum, Barium, Copper, Fluoride, Nickel, Nitrate Nitrogen, Zinc. domestic wastewater is treated by *an activated sludge plant operated in the extended aeration mode. Treatment units include a mechanical bar screen, grit chamber, oxidation ditch, final clarifiers, sludge holding basin, chlorine contact chambers, and a cascading aerator.*