

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Hutto, (CN: 600336861) operates the Central Wastewater Treatment Facility RN: 10311894. a conventional activated sludge wastewater treatment plant with an annual average discharge not to exceed 990,000 gallons per day. The fac 9. a conventional activated sludge wastewater treatment plant with an annual average discharge not to exceed 990,000 gallons per day. The facility is located 1300 feet east of FM Rd 1660 and 1500 feet south of State Hwy 79, in Hutto, Williamson County, Texas 78634.

The City of Hutto is applying to renew an existing Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0011324001.

Discharges from the facility are expected to contain Carbonaceous Biochemical Oxygen Demand (CBOD), Total Suspended Solids (TSS), Ammonia Nitrogen and E.col . Domestic wastewater is treated by a conventional activated sludge wastewater treatment plant.