

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

City of Jamaica Beach (CN601720766 ) operates Jamaica Beach Wastewater Treatment Plant RN102095684. a domestic wastewater treatment facility. The facility is located 16611 Marina Drive, in Jamaica Beach, Galveston County, Texas 77554.

This request is to renew the Discharge Permit for the wastewater treatment plant.

Discharges from the facility are expected to contain five-day Biochemical Oxygen Demand (BOD<sub>5</sub>), Total Suspended Solids (TSS). Additional potential pollutants are included in the Domestic Technical Report 1.0 ,Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by *one bar screen, two aeration basins two final clarifiers, two sludge digesters and two chlorine contact chambers.*

**RECEIVED**

AUG 31 2023

Water Quality Applications Team