

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of La Marque (CN600593412) operates Westside Wastewater Treatment Facility RN101917284. a domestic wastewater treatment facility. The facility is located at 2701B Woodland Street, in La Marque, Galveston County, Texas 77568.

This application is for a major amendment to expand the wastewater treatment plant. Current phase includes two identical plants side by side with a total design flow of 3.0 MGD. Two additional identical plants are proposed for a total design flow of 6.0 MGD. The treated effluent will discharge via Outfall 1. <<For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TDS), ammonia nitrogen (NH₃-N) and Escherichia coli. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7 Pollutant Analysis of Treated Effluent and Worksheet 4.0 Pollutant Analysis Requirements in the permit application package. Domestic wastewater is treated by mixed activated sludge with nitrification. Treatment units include aeration basins, clarifiers, chlorination, and de-chlorination.