

**ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT
APPLICATIONS**

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of New London (CN600683031) operates City of New London Sexton City Wastewater Treatment Facility RN101611721. a domestic wastewater treatment facility. The facility is located one mile southeast of the intersection of State Highway 42 and Farm to Market 918, in New London, Rusk County, Texas 75682.

To discharge treated wastewater at a volume not to exceed a daily average flow of 20,000 gallons per day.

Discharges from the facility are expected to contain BOD, TSS, E.coli.municipal wastewater will be treated by extended aeration wastewater treatment plant.The influent comes through a bar screen into the aeration basin. thence into a clarifier and

the effluent enters the chlorine contact chamber and out to the receiving stream. The settled sludge in the clarifier is either wasted to the digester or returned back to the aeration basin. .