

## Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

City of New Waverly (CN600680326 ) operates New Waverly Wastewater Plant No. 2 (RN101920957). a municipal wastewater treatment plant. The facility is located 200 Harris Road, in New Waverly, Walker County, Texas 77358.

Application to amend the existing TPDES permit to authorize the discharge of municipal wastewater not to exceed 0.3 million gallons per day

Discharges from the facility are expected to contain BOD<sub>5</sub>, total suspended solids, dissolved oxygen, total dissolved solids, nitrate nitrogen, ammonia nitrogen, sulfate, chloride, oil and grease, and E. Coli. Domestic wastewater in the interim phase is treated by *an oxidation ditch to the final clarifier; to the chlorine contact chamber; to the sludge drying beds. In the final phase the addition of a vortex grit removal system, carrousel aeration, a second final clarifier ultraviolet disinfection chamber and sludge drying beds.*

