

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Pasadena (CN600242648) operates Golden Acres Plant RN101609774. a plant is operated with oxidation ditch with surface aerators. The facility is located 100 yards south of Spencer Highway and adjacent to the west edge of Trebor Street , in Pasadena, Harris County, Texas 77505.

This application is for renewal to discharge a volume not to exceed a daily average flow of 10 million per day of treated wastewater via outfall.

Discharges from the facility are expected to contain 5-day carbonaceous biochemical oxygen demand (CBOD₅) total suspended solids (TSS), ammonia nitrogen (NH₃-N) and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Wastewater is treated by oxidation ditch with surface aerators. The plant includes screening, grit removal, aeration, clarifiers, sludge thickener, digester, chlorine contact chamber, post aeration, effluent pump station and belt filter presses.

