

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Point (CN600681993) operates East Treatment Plant RN 101612984. a pond facility that includes a bar screen, Oxidation ditch, and two stabilization ponds. The facility is located located at 127 locusts, approximately 2100 feet east of the intersection of farm-to-market road 47 and U.S. Highway 69, in Point, Rains County, Texas 75472.

The previous permit has expired and now must be submitted as a new wastewater system. <<For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain Biochemical Oxygen Demand, Total Suspended Solids, and E.coli. Residential Waste is treated by a race track Oxidation ditch and two stabilization ponds.