

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

#### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

City of San Marcos (CN600521272 ) operates San Marcos Wastewater Treatment Plant RN100838648. a wastewater treatment plant. The facility is located 720 River Road, in San Marcos, Hayes County, Texas 78666.

This application is for a renewal to discharge at an average annual rate of 9 MGD for treated domestic wastewater.

Discharges from the facility are expected to contain BOD<sub>5</sub>, CBOD<sub>5</sub>, total suspended solids, ammonia, and phosphorus. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by a headworks facility through primary clarifiers, aeration basins, secondary clarifiers, filters, UV channels and reaeration basins and then is discharged into the San Marcos River.

