

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

The City of Tenaha (CN600338065 ) operates the City of Tenaha wastewater treatment plan RN102844560. an activated sludge dewatering process. The facility is located on State Highway 96, in Tenaha, Panola County, Texas 75974.

This application is for a renewal to discharge treated wastewater not to exceed a daily average flow of 190,000 gallons per day.

Discharges from the facility are expected to contain treated municipal wastewater. Treated Municipal wastewater is treated by *influent bar screen followed by Imhoff tank, aeration basin and clarifier. Settled water flows through the UV disinfection and then to final discharge. Sludge is dewatered in one of the two sludge drying boxes before final disposal at permitted landfill.*

RECEIVED

OCT 12 2023

WATER QUALITY  
APPLICATIONS TEAM

### PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS