

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Waxahachie (CN600431415) operates the City of Waxahachie Wastewater Treatment Facility (RN102186970), an activated sludge process plant. The facility is located at 2301 Howard Road, in Waxahachie, Ellis County, Texas 75165.

This application is for a renewal to discharge at an annual average flow of 8,000,000 gallons per day of treated domestic wastewater via Outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential parameters are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by an activated sludge process plant. The treatment units include an influent collection box, fine screens, grit removal units, five aeration basins, five secondary clarifiers, sand filter basins, ultraviolet (UV) disinfection units, gravity thickener, sludge holding tanks, belt filter press, two screw presses, and four temporary sludge storage beds.

