

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Weslaco (CN600520969) operates Weslaco plant RN101607943. an Activated sludge process plant operated in extended aeration mode. The facility is located Northeast of the City of Weslaco approximately 4000 feet east of State Highway 88 and approximately 4000 feet North of Pike Boulevard , in Weslaco, Hidalgo County, Texas 78599.

This application is for renewal to discharge a volume not to exceed a daily average flow of 0.49 MGD of treated domestic wastewater via outfall.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅) total suspended solids (TSS), ammonia nitrogen (NH₃-N), Zinc and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater is treated by Activated sludge process plant operated in extended aeration mode, Treatment units include a lift station, bar screen, grit removal, oxidation ditches, secondary clarifiers, sludge belt press, chlorine contact chamber and dichlorination facilities.

