

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Clear Utilities, LLC (CN606085926) proposes to operate Field Creek Crossing wastewater treatment plant (RN#) with an average daily flow of 75,000 gallons per day. The facility will be located approximately 0.49 miles west of the intersection of Country Side Street and Cemetery Road, in Santa Fe, Galveston County, Texas 77517.

Discharges from the facility are expected to contain five-day biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids, ammonia nitrogen, and dissolved oxygen. Domestic wastewater will be treated by aeration/digester basins, a clarifier, and a chlorine contact chamber.