

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Columbia-Brazoria Independent School District (CN601102833)) operates Wild Peach Elementary WWTP (RN101179398). a Wastewater Treatment Plant. The facility is located approximately 1000 ft South of Wild Peach Elementary located on 3311 County Rd 353, in Brazoria, Brazoria County, Texas 77422.

13. Enter summary of application request here. <<For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain TSS, CBOD₅, Escherichia Coli, Ammonia Nitrogen (NH₃- N).Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater is treated by *activated sludge process plant operated in the extended aeration mode. Treatment units include a lift station, an aeration basin, a final clarifier and a chlorine contact chamber .*