

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

## **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Commodore Cove Improvement District (CN600624555 ) operates the Commodore Cove Wastewater Treatment Facility RN102286812. a domestic wastewater treatment facility.. The facility is located at 711 Anchor Drive, in Freeport, Brazoria County, Texas 77541.

Request for renewal of permit authorizing the discharge of 60,000 GPD of treated domestic wastewater.

Discharges from the facility are expected to contain BOD(5), Total Suspended Solids and Enterococci. Domestic wastewater is treated by *Extended aeration facility. Treatment units include; lift station, bar screen, secondary treatment process (oxidation ditch), clarifier, sludge holding basin, chlorine contact chamber.*

## **PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP**