

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Country Oaks MHP, LLC (CN606124790) operates Country Oaks Mobile Home Park Wastewater Treatment Facility (RN101202836). a domestic activated sludge wastewater treatment facility. The facility is located 6452 Nine Mile Bridge Road, in Fort Worth, Tarrant County, Texas 76135.

This application is for a renewal of TPDES Permit WQ0014046002 that authorizes the discharge of treated wastewater at a daily average flow not to exceed 16,000 gallons per day.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli* at levels not to exceed applicable water quality standards. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent, which is in the permit application package. Domestic wastewater is treated by an extended aeration basin, secondary clarifier, chlorine contact basin, effluent filters, and a sludge holding tank.

