

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS


DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Denton Stuart Ridge, LLC (CN N/A) proposes to operate Denton Stuart Ridge WWTP RN N/A. a MUD. The facility will be located Approximately 4140 feet north of FM 1173 and 490 feet west of Johnson Lane, in Krum, Denton County, Texas 76249.

New plant to discharge 1,200,000 gallons per day of treated domestic wastewater

Discharges from the facility are expected to contain five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), phosphorus (P), and dissolved oxygen (DO). Domestic wastewater will be treated by *an activated sludge process plant and the treatment units will include bar screens, aeration basins, secondary clarifiers, aerobic digesters, and chlorination chambers.*



PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS