

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

El Paso County Water Control and Improvement District #4 (CN600861637) operates Fabens Wastewater Treatment Plant RN101608164. an extended aeration treatment plant. The facility treats domestic, commercial, and industrial wastewater (RO Concentrate) by an extended aeration activated sludge process including mechanical step screen, grit removal chamber, selector tank, four aeration tanks, secondary clarifier, ultraviolet light (UV) disinfection. Sludge generated at the facility is treated by aerobic digestion and belt filter press before final disposal. The facility is located at 17270 Alameda Avenue, in Fabens, in El Paso County, Texas 79838.

This is the Renewal Permit Application for Permit No. WQ0010166001.

Discharges from the facility are expected to contain CBOD₅, TSS, NH₃-N, TDS, Total Chloride, DO, and E. Coli. Domestic, commercial, and industrial wastewater (RO Concentrate) are treated by an extended aeration activated sludge process including mechanical step screen, grit removal chamber, selector tank, four aeration tanks, secondary clarifier, and ultraviolet light (UV) disinfection. Sludge generated at the facility is treated by aerobic digestion and belt filter press before final disposal.