

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Fernco Development, Ltd., Lenco Development, Ltd., and Norco Development, Ltd. (CN 601581655; 601581697; 601581721) operates White Oak Manor Mobile Home Park Wastewater Treatment Facility RN101243210. a domestic wastewater treatment facility. The facility is located at 7200 White Oak Circle, in Houston, Harris County, Texas 77040.

Request for renewal of permit authorizing the discharge of 60,000 gallons of treated domestic wastewater per day.

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen and E. coli.. Domestic wastewater is treated by Activated sludge process. Treatment units include; aeration basin, clarifier, digester, chlorine contact chamber..



PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS