

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Fort Bend County Municipal Utility District No. 141 (CN 602562977) operates Fort Bend County MUD No. 141 Wastewater Treatment Facility (RN 106021736). an activated sludge process plant operated in the complete mix mode. The facility is located approximately 2650 ft east of intersection of Howell Rd and N St on the north side of West Fork Chocolate Bayou, in the City of Arcola, Fort Bend County, Texas 77583.

This application is for a renewal to discharge at an annual average flow of 700,000 gallons per day of treated domestic wastewater via an outfall

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a manual bar screen, aeration basins, final clarifiers, aerobic digesters, and chlorine contact chambers. The sludge is hauled off by a license sludge hauler for disposal.

