

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Gram Vikas Partners, Inc. (CN605577949) proposes to operate Hondo Creek Farm Wastewater Treatment Plant (No RN Number – New Facility), a corporation. The facility will be located approximately 0.2 miles west of the intersection of CR 341 and CR 442, in Hondo, Medina County, Texas 78861.

New TPDES permit application to discharge up to 300,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain daily average concentrations not to exceed 5.0 mg/L BOD₅, 5.0 mg/L TSS, 2.0 mg/L NH₃-N, 1.0 mg/L total phosphorus, and 126 CFU/100 mL E.coli. Domestic wastewater will be treated by a *package membrane bio-reactor (MBR) wastewater treatment plant.*

