

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Greenwood Land Holding Company, LLC (CN Unknown) proposes to operate Waller County Mud No. 53 RN Unknown. an Domestic Wastewater Treatment Plant. The facility will be located 27828 Kickapoo Rd, in Hockley, Waller County, Texas 77353.

This application is for a new TPDES permit to discharge a daily flow of 240,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain ¹⁴. List all expected pollutants here.. Domestic Wastewater Processing plant will be treated by a bar screen, a grit chamber, aeration basin, final clarifiers, sludge digester, a belt filter press, and chlorine contact chamber..