

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

#### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Harris County Water Control and Improvement District No. 113 (CN 600741565 ) operates the Harris County Water Control and Improvement District No. 113 RN 102335403. a domestic wastewater treatment plant. The facility is located at 14601 Enchanted Valley Drive, in Cypress, Harris County, Texas 77429.

This application is for a renewal to discharge at an average flow up to 300,000 gallons per day of treated domestic wastewater via Outfall OO1.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N) and Escherichia coli. Domestic wastewater is treated by an activated sludge process. Treatment units include a fine screen, an aeration basin, a final clarifier, sludge digesters, and a chlorine contact chamber. .

SEE ATTACHMENT I