

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Harris County Water Control and Improvement District No. 84 (CN600801484) operates Harris County Water Control & Improvement District No. 84 Wastewater Treatment Plant RN104008503. a domestic wastewater treatment facility. The facility is located at 16224 Bear Bayou Drive, in Channelview, Harris County, Texas 77530.

Harris County Water Control & Improvement District No. 84 has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010558001 to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 2,000,000 gallons per day.

Discharges from the facility are expected to contain Ammonia Nitrogen, Nitrate Nitrogen, Sulfate, Chloride, and Phosphorus. Domestic wastewater is treated by *an activated sludge process plant and the treatment units include an aeration basin, two clarifiers, a digester, and a chlorine contact chamber.*

**PLANTILLA EN ESPAÑOL PARA SOLICITUDES
NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP**

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

Harris County Water Control & Improvement District No. 84 (CN 600801484) opera Harris County Water Control & Improvement District No. 84 Wastewater Treatment Plant (RN 104008503) una planta de tratamiento de aguas residuales usando cloro para tratar agua residuales. La instalación esta ubicado en 16224 Bear Bayou Drive, en Channelview, Condado de Harris, Texas 77530.

Applica para renovar una aplicación para descargar 2,000,000 galones de aguas residuales tratado.

Se espera que las descargas de la instalación contengan nitrógeno amoniacal, nitrógeno nitrato, sulfato, chloruro, y fósforo. Las aguas residuales están tratado por una planta de proceso de lodos activos y las unidades de tratamiento incluye un aeration basin, un digester, dos clarifiers, y un chlorine contact chamber.