

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Harris County Water Control and Improvement District No. 84 (CN600801484) operates Harris County Water Control & Improvement District No. 84 Wastewater Treatment Plant RN104008503, a domestic wastewater treatment facility. The facility is located at 16224 Bear Bayou Drive, in Channelview, Harris County, Texas 77530.

Harris County Water Control & Improvement District No. 84 has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010558001 to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 2,000,000 gallons per day.

Discharges from the facility are expected to contain Ammonia Nitrogen, Nitrate Nitrogen, Sulfate, Chloride, and Phosphorus. Domestic wastewater is treated by *an activated sludge process plant and the treatment units include an aeration basin, two clarifiers, a digester, and a chlorine contact chamber.*