

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

HMH Caddo Mills Land, L.P. (CN N/A ) proposes to operate Hunt County Municipal Utility District No. 5 Wastewater Treatment Facility (RN N/A). an activated sludge process plant.. The facility will be located approximately 3,802 ft northwest of the intersection of I-30 Frontage Road and Cantrell Boulevard, in Caddo Mills, Hunt County, Texas 75135.

New application to discharge 0.25 MGD design flow of treated domestic wastewater.

Discharges from the facility are expected to contain five-day biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), phosphorus (P), and dissolved oxygen (DO). Domestic wastewater will be treated by *an activated sludge process plant and the treatment units will include bar screens, aeration basins, secondary clarifiers, aerobic digesters, and chlorination chambers.*

