

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS


DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Chuong Anh Nguyen (CN604360412) operates The Southgate Wastewater Treatment Facility RN102915378. a domestic wastewater treatment facility. The facility is located at 10155 North Freeway, in Houston, Harris County, Texas 77037.

Request for renewal of permit authorizing the discharge of 32,000 gallons of treated domestic wastewater per day.

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen, Total Kjeldahl Nitrogen and E. coli. Domestic wastewater is treated by **Stage 1 Nitrification Process: Flow is from the lift station into aeration; thence to clarifier, thence to chlorine contact basin; thence to ditch. Process also includes digester, blowers and chlorination equipment.**



PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS