

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Hooks Mobile Home Park, Ltd., (CN601178698) operates the Hooks Mobile Home Park Wastewater Treatment Facility (RN102177698), a domestic wastewater permit. The facility is located at 12019 Aldine Westfield Road, Houston, in Harris County, Texas, 77093.

Renewal to discharge 60,000 gallons per day of treated domestic wastewater. Discharges from the facility are expected to contain: CBOD(5), Total Suspended Solids, Ammonia Nitrogen, Total Kjeldahl Nitrogen and E. coli. This is a .06 MGD facility operated in a complete mix modification of the activated sludge process. The treatment units include the following: aeration chamber, clarifier, chlorine contact chamber and 3 digesters.

