

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Horizon Regional Municipal Utility District (CN601229560) operates the Horizon Regional Municipal Utility District Wastewater Treatment Facility RN102329075. an existing wastewater treatment facility which utilizes the activated sludge process and discharges treated effluent in accordance with TCEQ permit standards. The facility is located at 13223 Berkley Drive, in Horizon City, El Paso County, Texas 79928.

Horizon Regional Municipal Utility District is requesting renewal of the existing discharge permit with the existing and operating facilities.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and Escherichia coli. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7 and Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Municipal wastewater is treated by biological treatment with activated sludge treatment for disposal.

