

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

New Ulm Water Supply Corporation (CN600628705) operates New Ulm WSC Wastewater Treatment Plant RN 103136826, a wastewater collection and treatment plant. The facility is located at 24056 Bernard Road, in New Ulm, Austin County, Texas 78950.

Summary: Request to renew our current TPDES permit WQ0013655001, to discharge up to an annual average daily flow of 50,000 gallons per day of treated domestic wastewater via Outfall 001

Discharges from the facility are expected to contain total suspended solids (TSS), biochemical oxygen demand (BOD₅) and Escherichia coli. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, aeration basins, re-air zone, final clarifier, sludge digesters, and chlorine contact chamber.