

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Niazi Family Investments, Ltd. (CN603616152) operates King Fuels 100589555. a domestic wastewater treatment facility. The facility is located at 17141 East Freeway, in Channelview, Harris County, Texas 77530.

Request for renewal of a domestic wastewater permit authorization the discharge of 8,000 gallons of treated domestic wastewater per day.

Discharges from the facility are expected to containCBOD(5), Total Suspended Solids, Ammonia Nitrogen and E.coli.Domestic Wastewater is treated by *activated sludge in the extended aeration mode*-**Domestic waste influent enters aeration basin, then flows to clarifier. Solids are sent to digester, liquids flow to chlorine contact chamber, then are discharged into a drainage ditch. .**



PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS