

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Protestant Episcopal Church Council of the Diocese of Texas, Camp Allen (CN603576430) operates Camp Allen Wastewater Treatment Facility RN101525483. a private Retreat and Conference Center. The facility is located 18800 FM 362, in Navasota, Grimes County, Texas 77868.

Renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.0335 million gallons per day (MGD).

Discharges from the facility are expected to contain BOD₅-10PPM, TSS-15PPM, NH₃-3PPM, DO-4PPM. Domestic wastewater is treated by *Conventional wastewater treatment plant.*

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP