

PLAIN LANGUAGE SUMMARY

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Quadvest, LP (CN602944746) operates the Benders Landing Wastewater Treatment Facility (RN105097521), an activate sludge processing plant operating in the conventional plug flow mode. The facility is located at 27922 Inspire Crest Lane, Spring, Montgomery County, Texas

This is a renewal application with no major or minor amendments.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater will be treated by an activated sludge process plant and the treatment units will include a bar screen, aeration basins, final clarifiers, sludge digesters and chlorine contact chambers.