

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Riverside Utilities, LLC and Vista Townhomes Austin, LLC propose to operate Vista Townhomes Wastewater Treatment Facility, a conventional activated sludge facility with membrane bioreactor (MBR) solids separation. The facility will be located approximately 0.4 miles north of the intersection of Vista Heights Drive and State Highway 29 West, near Georgetown, Williamson County, Texas 78628.

This application is for a new permit to discharge treated domestic wastewater at a daily average flow of 360,000 gallons per day via Outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N) and *Escherichia coli*. Domestic wastewater will be treated by a conventional activated sludge facility with MBR solids separation. The treatment units include a headworks with automatic fine screen, a flow equalization (EQ) tank, aeration basins with MBR solids separation (MBR skid), ultraviolet light (UV) disinfection, a sludge holding tank, and a sludge dewatering screw press.

